



**CONCRETE SLAB ON GRADE SCHEDULE**

**S1**  
150 CONCRETE SLAB ON MINIMUM 150 WELL  
COMPACTED GRANULAR BASE, MINIMUM 300 WELL  
COMPACTED GRANULAR SUB-BASE R/W 10M @ 400 O/C  
EA. WAY TOP

**S2**  
150 CONCRETE SLAB ON MINIMUM 150 WELL  
COMPACTED GRANULAR BASE, MINIMUM 300 WELL  
COMPACTED GRANULAR SUB-BASE R/W 15M L-  
DOWELS @ 300 O/C TOP, 10M TRANSVERSE @ 400 O/C.  
PROVIDE MINIMUM 150mm VOID FORM 1220 FROM  
FACE OF THICKENED EDGE AT FULL WIDTH OF MAN-  
DOOR OPENING ONLY.

NOTE:  
ADDITIONAL BACKFILL IS REQUIRED AROUND THE  
SHED PERIMETER TO TIE INTO EXISTING ADJACENT  
GRADES. REFER TO ARCHITECTURAL SITE PLAN FOR  
EXTENT AND TYPE OF BACKFILL FOR FINISH GRADE  
CONDITION. BACKFILL UNDER THE SLAB, APRON AND A  
45 DEGREE SPLAY BELOW THESE ELEMENTS SHALL BE  
COMPACTED GRANULAR FILL. PROVIDE FIELD  
COMPACTION TESTING TO VERIFY COMPACTION TO  
98% STANDARD PROCTOR.



**1 MAIN FLOOR FRAMING PLAN**  
S201 1 : 75

