



284-2018 ADDENDUM 1

SUPPLY AND INSTALLATION OF FIRE ALARM SYSTEM AT 2170 MAIN STREET

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: July 3, 2018
BY: Ken Pietracci
TELEPHONE NO. 204 794-4047

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, **July 13, 2018**.

PART D – SUPPLEMENTAL CONDITIONS

Revise: D12.1 to read: The Contractor shall achieve Substantial Performance within **sixty (60)** consecutive Working Days of the commencement of the Work as specified in D11.

Revise: D13.1 to read: The Contractor shall achieve Total Performance within **sixty-five (65)** consecutive Working Days of the commencement of the Work as specified in D11.

PART E – SPECIFICATIONS

Add: E1.3 The following are applicable to the Work:

<u>Drawing No.</u>	<u>Drawing Name/Title</u>
1-R0	284-2018_Drawing_1-R0

Add: E2.21 All office areas, washrooms, cooking areas and mechanical rooms shall be protected by heat detection devices.

Add: E2.22 Corridors and Hallways servicing office areas shall be protected by smoke detection devices.

DRAWINGS

Add: **284-2018_Drawing_1-R0**