



NOTES:
 1. CONFIGURE FLOW METER, FIT-008 FOR 4-20mA PASSIVE OUTPUT.

File Name: c:\project\is\working directory\active\40s\k\0631074175009-21-mccarthy-loops.dwg

		 DILLON CONSULTING		 THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION		DESIGNED BY B.L.M.	CHECKED BY B.L.M.	REHABILITATION OF PUBLIC WATER SERVICE OUTLETS: BILLING SYSTEM, BUILDING SUPPLY, DEMOLITION AND ELECTRICAL McCARTHY STREET 0802-FIT-008 LOOP DIAGRAM	SHEET 17 OF 18
0	ISSUED FOR BID OP 330-2018	18/04/19	B.L.M.	DATE: 17/07/06	PROJECT No. 175009	DRAWN BY S.C.K.	APPROVED BY		CITY DRAWING NUMBER D-14938
NO.	REVISION	DATE	BY						