

	<b>Lamacoid Schedule</b>		Document Code	648185-0000-40EL-0001
			Revision	00
Client City of Winnipeg				
Project Metro Route 20 Underpass Pumping Station Upgrades				
Package / Area				
Prepared By	Name	Signature	Date	
	B. Cleven		2018/05/09	
Checked By	Name	Signature	Date	
	B. Cleven		2018/05/09	
Approved By	Name	Signature	Date	
	B. Cleven		2018/05/09	
Notes / Comments				

Revisions					
Rev	Description	Date	By	Checked	Approved
00	Issued for Tender	2018/05/09	B. Cleven	B. Cleven	B. Cleven

ID No.	Line 1	Line 2	Line 3	Size (mm)	Note
1	AE-U550	Methane Gas	Sensor	5	
2	AIT-U550	Methane Gas	Detector	5	
3	EF-U63	Wetwell Exhaust Fan		8	
4	EF-U64	Roof Exhaust Fan		8	
5	FIL-U61	Main Floor Air Filter		8	
6	FIL-U62	Wetwell Air Filter		8	
7	FV-U613	Main Floor Ventilation	Intake Air	5	
8	FV-U614	Main Floor Ventilation	Return Air	5	
9	FV-U615	Main Floor Ventilation	Exhaust Air	5	
10	HCE-U61	Main Floor Duct Heater		8	
11	HCE-U62	Wetwell Duct Heater		8	
12	HS-U601	Main Floor Occupancy		5	
13	HS-U602	Wetwell Occupancy		5	
14	ISL-U610	Main Floor Ventilation	Supply Fan Current Switch	5	
15	LE-U500	Wetwell Level Sensor		5	
16	PDSH-U611	Main Floor Air Filter	Pressure Switch	5	
17	PDSH-U621	Wetwell Air Filter	Pressure Switch	5	
18	P-U01			12	
19	P-U02			12	
20	SF-U61	Main Floor Supply Fan		8	
21	SF-U62	Wetwell Supply Fan		8	
22	TE-U612	Main Floor Discharge	Air Temperature Sensor	5	
23	TE-U622	Wetwell Discharge	Air Temperature Sensor	5	
24	TE-U665	Generator Damper Control	Temperature Sensor	5	
25	TIC-U620	Wetwell Discharge Air	Temperature Controller	5	
26	TIC-U660	Generator Cooling	Damper Controller	5	
27	TSH-U641	High Temp. Switch	Roof Exhaust Fan Control	5	
28	TSL-U651	UH-U65 Thermostat		5	
29	TS-U601	Building Hi/Low Temperature		5	
30	TV-U663	Generator Cooling	Return Air	5	
31	TV-U664	Generator Cooling	Exhaust Air	5	
32	UH-U65			8	
33	UIC-U610	Main Floor Ventilation	Temp. & Damper Controller	5	
34	XV-U623	Wetwell Supply Fan	Air Damper	5	
35	XV-U631	Wetwell Exhaust Fan	Air Damper	5	
36	XV-U642	Roof Exhaust Fan	Damper	5	
37	XV-U661	Combustion	Air Damper	5	
38	XV-U662	Generator Cooling / Roof Exhaust Fan	Intake Air	5	

Notes:

1. This schedule is provided for reference only and the potential omission of any lamacoids on this schedule does not reduce the contractor's responsibility in providing lamacoids as specified.
2. Cable tags are not shown. Lighting and receptacle labels are not shown.
3. Lamacoids required for control panels and junction boxes specified to be manufactured by a panel shop are not shown.