


FUSE SCHEDULE			
TB	IDENTIFIER	SIZE	RATING
TB11	F11	5x20mm	5A TD
	F12	5x20mm	1A FA
	F13	5x20mm	1A FA
TB12	F21	5x20mm	5A TD
	F22	5x20mm	1A FA
	F23	5x20mm	1A FA

NOTES
 FA = FAST ACTING
 TD = TIME DELAY

LAST SAVE: 2018/08/27 - 9:23am
 PATH: P:\Projects\2018\18-0107-007 Dwg [Elec]\1-0102-ACBD-P302-001.dwg

REFERENCE DRAWINGS	DESCRIPTION



NO.	REVISIONS	DATE	DESIGN	CHECK
00	ISSUED FOR CONSTRUCTION - 682-2018	2018/08/27	DDW	JAB

KGS GROUP
CONSULTING ENGINEERS

DESIGNED BY: D. WILSON
 CHECKED BY: J. BOUCHARD

DRAWN BY: G. NELSON
 APPROVED BY: D. WILSON

SCALE: AS SHOWN
 ISSUED FOR CONSTRUCTION BY: B. STATION

DATE: 2018/07/20
 DATE: 2018/08/27

CONSULTANT NO.: 1-0102-ACBD-P302-001

ENGINEER'S SEAL

THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT

SOUTH END WATER POLLUTION CONTROL CENTRE
 TRAVELLING BRIDGES REFURBISHMENT
 AUTOMATION - POWER DISTRIBUTION SCHEMATIC
 PRIMARY CLARIFIERS
 LCP-P301-1, TRAVELLING BRIDGE PLC CABINET - PLC-301

CITY DRAWING NUMBER: 1-0102-ACBD-P302-001
 SHEET: 001
 REV: 00
 SIZE: A1