


| FUSE SCHEDULE | | | |
|---------------|------------|--------|--------|
| TB | IDENTIFIER | SIZE | RATING |
| TB11 | F11 | 5x20mm | 5A TD |
| | F12 | 5x20mm | 1A FA |
| | F13 | 5x20mm | 1A FA |
| TB12 | F21 | 5x20mm | 5A TD |
| | F22 | 5x20mm | 1A FA |
| | F23 | 5x20mm | 1A FA |

NOTES
 FA = FAST ACTING
 TD = TIME DELAY

LAST SAVE: 2018/08/27 - 9:24am
 PATH: P:\Projects\2018\18-0107-007 Dwg [Elec]\1-0102-ACBD-P306-001.dwg

| REFERENCE DRAWINGS | DESCRIPTION |
|--------------------|-------------|
| | |



| NO. | REVISIONS | DATE | DESIGN | CHECK |
|-----|------------------------------------|------------|--------|-------|
| 00 | ISSUED FOR CONSTRUCTION - 682-2018 | 2018/08/27 | DDW | JAB |

KGS GROUP
 CONSULTING ENGINEERS

DESIGNED BY: D. WILSON
 CHECKED BY: J. BOUCHARD
 DRAWN BY: G. NELSON
 APPROVED BY: D. WILSON
 SCALE: AS SHOWN
 ISSUED FOR CONSTRUCTION BY: B. STATION
 DATE: 2018/07/20
 DATE: 2018/08/27
 CONSULTANT NO.: 1-0102-ACBD-P306-001

ENGINEER'S SEAL

THE CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT

SOUTH END WATER POLLUTION CONTROL CENTRE
 TRAVELLING BRIDGES REFURBISHMENT
 AUTOMATION - POWER DISTRIBUTION SCHEMATIC
 PRIMARY CLARIFIERS
 LCP-P302-1, TRAVELLING BRIDGE PLC CABINET - PLC-302

CITY DRAWING NUMBER: 1-0102-ACBD-P306-001
 SHEET: 001
 REV: 00
 SIZE: A1