



FUSE SCHEDULE			
TB	IDENTIFIER	SIZE	RATING
TB11	F11	5x20mm	5A TD
	F12	5x20mm	1A FA
	F13	5x20mm	1A FA
TB12	F21	5x20mm	5A TD
	F22	5x20mm	1A FA
	F23	5x20mm	1A FA

NOTES
 FA = FAST ACTING
 TD = TIME DELAY

REFERENCE DRAWINGS	DESCRIPTION



NO.	REVISIONS	DATE	DESIGN	CHECK
00	ISSUED FOR CONSTRUCTION - 682-2018	2018/08/27	DDW	JAB

KGS GROUP CONSULTING ENGINEERS	
DESIGNED BY: D. WILSON	CHECKED BY: J. BOUCHARD
DRAWN BY: G. NELSON	APPROVED BY: D. WILSON
SCALE: AS SHOWN	ISSUED FOR CONSTRUCTION BY: B. STATION
DATE: 2018/07/20	DATE: 2018/08/27
CONSULTANT NO.: 1-0102-ACBD-P314-001	

ENGINEER'S SEAL

THE CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT

SOUTH END WATER POLLUTION CONTROL CENTRE
 TRAVELLING BRIDGES REFURBISHMENT
 AUTOMATION - POWER DISTRIBUTION SCHEMATIC
 PRIMARY CLARIFIERS
 LCP-P301-2, TRAVELLING BRIDGE PLC CABINET - RIO-301

CITY DRAWING NUMBER 1-0102-ACBD-P314	SHEET 001	REV. 00	SIZE A1
--	---------------------	-------------------	-------------------