



| FUSE SCHEDULE |            |        |        |
|---------------|------------|--------|--------|
| TB            | IDENTIFIER | SIZE   | RATING |
| TB11          | F11        | 5x20mm | 5A TD  |
|               | F12        | 5x20mm | 1A FA  |
|               | F13        | 5x20mm | 1A FA  |
| TB12          | F21        | 5x20mm | 5A TD  |
|               | F22        | 5x20mm | 1A FA  |
|               | F23        | 5x20mm | 1A FA  |

NOTES  
 FA = FAST ACTING  
 TD = TIME DELAY

| REFERENCE DRAWINGS | DESCRIPTION |
|--------------------|-------------|
|                    |             |



| NO. | REVISIONS                          | DATE       | DESIGN | CHECK |
|-----|------------------------------------|------------|--------|-------|
| 00  | ISSUED FOR CONSTRUCTION - 682-2018 | 2018/08/27 | DDW    | JAB   |

**KGS GROUP**  
 CONSULTING ENGINEERS

DESIGNED BY: D. WILSON  
 CHECKED BY: J. BOUCHARD

DRAWN BY: G. NELSON  
 APPROVED BY: D. WILSON

SCALE: AS SHOWN  
 ISSUED FOR CONSTRUCTION BY: B. STATION

DATE: 2018/07/20  
 DATE: 2018/08/27

CONSULTANT NO.: 1-0102-ACBD-P322-001

ENGINEER'S SEAL

**THE CITY OF WINNIPEG**  
 WATER AND WASTE DEPARTMENT

SOUTH END WATER POLLUTION CONTROL CENTRE  
 TRAVELLING BRIDGES REFURBISHMENT  
 AUTOMATION - POWER DISTRIBUTION SCHEMATIC  
 PRIMARY CLARIFIERS  
 LCP-P311-2, TRAVELLING BRIDGE PLC CABINET - RIO-P311

CITY DRAWING NUMBER: 1-0102-ACBD-P322-001  
 SHEET: 001  
 REV: 00  
 SIZE: A1