



717-2018 ADDENDUM 1

REDEVELOPMENT OF CRESCENT DRIVE PARK PAVILION – 781 CRESCENT DRIVE

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: September 26, 2018
BY: John Atkinson
TELEPHONE NO. 204 794-4418

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, October 1, 2018.

QUESTIONS AND ANSWERS

Q1 How far are the 3" conduits to go?

R1 The 3" conduit for future telecommunications should be installed as per 3/E1.0. No clarifications required.

Q2 How far away is the CSTE?

R2 Electrical Contractor is to provide 100m of conduit, wire and associated trenching from CSTE to service entrance to coordinate with Manitoba Hydro service pole location.

DRAWINGS

Replace: 717-2018_Drawing_A-SP1-R0 with 717-2018_Addendum_1_Drawing_A-SP1-R1
717-2018_Drawing_A-SP2-R0 with 717-2018_Addendum_1_Drawing_A-SP2-R1
717-2018_Drawing_L-100-R0 with 717-2018_Addendum_1_Drawing_L-100-R1
717-2018_Drawing_A-200-R0 with 717-2018_Addendum_1_Drawing_A-200-R1
717-2018_Drawing_EL2.0-R0 with 717-2018_Addendum_1_Drawing_EL2.0-R1
717-2018_Drawing_S-3-R0 with 717-2018_Addendum_1_Drawing_S-3-R1

SUBSTITUTIONS

The following have been approved as equals in accordance with B7.

Architectural

Division 08 Openings
Section 08 71 00 Door Hardware

Specified Product	Approved Equal Product
Norton 6020	Nabco GyroTech GT8500

Electrical

Specified Product	Approved Equal Product
LF-1 Lithonia VAP 4000LM FST WD MVOLT GZ10 30K 90CRI	Phillips V3W443L830-UNV-DIM-TR-LFA // V3WSBK
LF-2 Lithonia DMW2 L24 2000LM PFL WD MVOLT GTZ1 30K 90CRI	Phillips V3W227L830-UNV-DIM-TR-LFA // V3WSBK
LF-5 Lithonia ZL1N L48 5000LM PST MVOLT 30K 90CRI WH	Phillips FSS455L830-UNV-DIM
Combination Emergency Light Exit Sign AIMLITE CARPW12721M-2MD/6LA-WHT	Phillips EAC1W12802LJ
Double Remote Head AIMLITE RMMD2-126WLAWHT	Phillips EF9DM-LJ