


2 ROOF PLAN E3 SCALE: N.T.S.



EPL Ga, ZONE 2, GROUP IIA

EPL Gb, ZONE 2, GROUP IIA

NON-HAZARDOUS

HAZARDOUS AREA CLASSIFICATION:

- ALL ELECTRICAL SYSTEM, EQUIPMENT AND INSTALLATION LOCATED IN HAZARDOUS CLASSIFIED AREAS TO CONFORM TO THE REQUIREMENTS OF WINNIPEG ELECTRICAL BYLAW AND LOCAL INSPECTION HAVING JURISDICTION.
- 2. 1.5m BEYOND EVERY OPENING SHALL BE CONSIDERED CLASSIFIED SAME AS IN THE SANITARY MANHOLE.
- 3. 1.5m BEYOND THE BALLOON AROUND THE OPENING SHALL BE CONSIDERED CLASSIFIED TO NEXT STEP BELOW IN THE HAZARDOUS CLASSIFICATION CHART.
- 4. THE AREA CLASSIFICATION OF NEW MANHOLES NEAR PUMP AND ACTUATOR CHAMBERS SHALL BE SAME AS THE 2 CHAMBERS SHOWN HERE.

ENGINEERS GEOSCIENTISTS MANITOBA Certificate of Authorization WSP Canada Inc. No. 5750

G.B.N ELEV				11	5)		GP Canada Group Limited mbard Avenue, Suite 111 Winnipeg MB R3B 3B1 T+ 1 204-943-3178 F+ 1 204-943-4948 www.wsp.com	ENGINEER'S SEAL E.N.	· Comment
				DESIGNED BY	AE	CHECKED BY	ES	SAPNU MEMBER 22983 10/09/2018	WEEK
				DRAWN BY	AE	APPROVED BY	ES	PROFESSION P	
3	ISSUED FOR TENDER	14/09/18	ES	1100 00415	AS NOTED		Signed by KZ	MOFESSION	
2	ISSUED FOR REVIEW	15/08/18	ES	HOR. SCALE		RELEASED FOR CONSTRUCTION	September	BID OPPORTUNITY: 865_201	0
1	ISSUED FOR REVIEW	12/12/16	HP	VERTICAL	AS NOTED	CONCINCOTION	14, 2018	BID OPPORTUNITY: 865-2018	D
NO.	REVISIONS	DATE	BY	DATE		DATE		PLOT DATE: 10/09/201	8

BID OPPORTUNITY: 865-2018

THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT

OUTFALL GATE CHAMBER UPGRADES **AUBREY STREET** SRS OUTFALL GATE CHAMBER

DETAILS AND

AREA CLASSIFICATION

	CONSULTANT DRAWING NUMBER								
	5516047 - E03								
	SHEET		OF						
		14		33					
	LD-8026								