

962-2018 ADDENDUM 2

FORT ROUGE TRANSIT BASE STORAGE TRACK 13-24 MECHANICAL UPGRADE

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: December 5, 2018
BY: Jeff Horrocks, P.Eng.
TELEPHONE NO. 204 789-2332

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

NMS FORMAT SPECIFICATIONS

- Revise: 1.2.6.23 of 21 05 10 to read: Vertical in-line pumps* Armstrong; Taco; Bell & Gossett
- Add: 2.3.1.2 of 21 08 10 to read: On pipes 62mm (2-1/2") diam. and larger, use 25mm (1") Fibreglas 88 kg/m (5-1/2 lb./cu. ft.) density pipe insulation with ASJ jacket, c/w vapour barrier.
- Add: 2.3.2.2 of 21 08 10 to read: Vent piping for a developed length of 3m (10'-0") from roof terminals.
- Add: 2.3.2.3 of 21 08 10 to read: Infrared heater intake piping from roof to infrared heater.

QUESTIONS AND ANSWERS

- Q1 What is the volume of the existing buffer tank?
A1 129 gallons.
- Q2 Are the existing IR heater vents through the exterior wall to be removed? It will be difficult to match existing exterior surface.
A2 Existing vent through exterior wall to remain. Cap vent at interior of wall.
- Q3 Do the new IR heaters require fresh air inlets?
A3 Yes, provide combustion air intakes from the roof to each IR heater.
- Q4 Is the existing MUA-14 roof curb to be removed or just cover roof curb with a sealed metal flashing?
A4 Existing curb to be covered and sealed in accordance with section 07 52 16.
- Q5 Are just the new pumps (P-7 and P-8) to be balanced or are all the pumps in the mechanical to be balanced?
A5 Existing pumps P-1, P-2, P-5 and P-6 and new pumps P-7 and P-8 shall be balanced to flows noted on drawing M2.6.
- Q6 Please confirm hydronic pipe size tie-in (keynote 6 on M2.5) as the existing piping on site appears to be 6".
A6 Existing hydronic piping is 6". Piping shall be 6" from existing piping to 4" branch piping serving HRU-5/6.