

AIR HANDLING UNIT SCHEDULE																																			
MARK	MAKE	MODEL	ZONE SERVED	SUPPLY AIRFLOW		SUPPLY FAN E.S.P.		BLOWER QUANTITY		FAN AIRFLOW (EA.)		FAN POWER (EA.)		PRE-HEAT COIL (TOTAL COILS)				COOLING COIL				DESIGN WEIGHT	MAXIMUM DIMENSIONS (WxDxH)		NOTES										
				(cfm)	(L/s)	("w.c.)	(Pa)	(CFM)	(L/s)	(hp)	(kW)	(Btu/h)	(kW)	(GPM)	(L/s)	(°F/°C)	(°F/°C)	(Btu/h)	(kW)	(GPM)	(L/s)		(°F/°C)	(°F/°C)		(mm)	(in)								
AHU 1	CARRIER	39MN SIZE 21W	AUDITORIUM	7600	3587	1.50	373	2	7600	3587	10.00	7.46	272000	80	30.20	1.91	9.20	27.50	216000	63	18.0	115000	34	44.00	2.78	13.60	40.65	50mm MERV8 / 300mm MERV14	575 V	3	3092	1458	2134X3213X1500	84X128X60	1, 4
AHU 2	CARRIER	39MN SIZE 17W	LOBBY	5600	2643	1.50	373	2	5600	2643	10.00	7.46	187000	55	20.80	1.31	0.40	1.20	159000	47	13.3	105000	31	32.00	2.02	4.70	14.05	50mm MERV8 / 300mm MERV14	575 V	3	2728	1287	2007X3175X1270	79X126X50	1, 4
AHU 3	CARRIER	39mn size 03W	BASEMENT	1100	519	1.50	373	2	1100	519	1.50	1.12	33000	10	3.66	0.23	0.00	0.00	29000	8	2.4	22500	7	6.00	0.38	0.80	2.39	50mm MERV8 / 300mm MERV14	575 V	3	1228	579	825X1152X925	33X96X37	1, 4
AHU 4	CARRIER		SENIORS CENTRE (FUTURE)	6000	2832	1.00	249				0.00	0.00																575 V	3	0	0			5	
DHU 1	DECTRON	LD-092-NT	POOL	11320	5342	1.00	249	2	11320	5342	15.00	11.19	155000	45	16.50	1.04	11.50	34.37	224700	66	18.7	122000	36	45.00	2.84	3.69	11.03		575 V	3	8400	4434	6096X2286X2134	240X90X84	1, 2, 3, 4

- PROVIDE WITH CONTROL PANEL TO INTERFACE WITH BACNET BUILDING CONTROLS SYSTEM
- SELECT WITH 2000 CFM OUTDOOR AIR AND 2200 CFM EXHAUST AIR.
- PROVIDE 35% GLYCOL RUMAROUND COIL FOR HEAT RECOVERY.
- HEATING COIL TO BE SELECTED FOR 35% PG.
- AHU-4 SHOWN AS PLACEHOLDER FOR FUTURE USE.

FAN COIL SCHEDULE														
MARK	MAKE	MODEL	ZONE SERVED	SUPPLY AIRFLOW		SUPPLY FAN E.S.P.		MINIMUM O/A		MAXIMUM WEIGHT		VOLTAGE	PHASE	NOTES
				(cfm)	(L/s)	("w.c.)	(Pa)	(cfm)	(L/s)	(lbs)	(kg)			
FC 1	CARRIER	42DC08B	DRESSING ROOM	500	236	0.50	124	75	35	MERV 8	94	43	120 V	1
FC 2	CARRIER	42DC06B	LUNCH ROOM	500	236	0.50	124	60	28	MERV 8	94	43	120 V	1
FC 3	CARRIER	42DC08B	CLASSROOM	400	189	0.50	124	150	71	MERV 8	94	43	120 V	1
FC 4	CARRIER	42DC08B	OFFICE 98	140	66	0.50	124	50	24	MERV 8	94	43	120 V	1
FC 5	CARRIER	42DC08B	OFFICE 77	140	66	0.50	124	50	24	MERV 8	94	43	120 V	1

HEAT/ENERGY RECOVERY VENTILATION UNIT SCHEDULE																												
MARK	MAKE	MODEL	RECOVERY CORE WINTER PERFORMANCE				SUPPLY AIRFLOW		EXHAUST AIRFLOW		SUPPLY FAN E.S.P.		SUPPLY FAN POWER		EXHAUST FAN E.S.P.		EXHAUST FAN POWER		MAXIMUM DIMENSIONS			MAXIMUM WEIGHT		ELECTRICAL		NOTES		
			MIN. SENSIBLE EFFICIENCY (%)	ENT AIR TEMP (F)	ENT AIR TEMP (C)	LVG AIR TEMP (F)	LVG AIR TEMP (C)	MAX. CORE VELOCITY (fpm)	(cfm)	(L/s)	(cfm)	(L/s)	("w.c.)	(Pa)	(hp)	(kW)	("w.c.)	(Pa)	(hp)	(kW)	FILTERS	HEIGHT	LENGTH	WIDTH	(lbs)		(kg)	VOLTAGE
ERV 1	PRICE	PRC5000	86.6	-40	-40	55	13	6000	2832	6000 CFM	2832 L/s	1.0	249	5.00	3.73	1.5 in-wg	373 Pa	5.00 hp	3.73 kW	MERV 8	1981	3962	1829	7500	3402	575 V	3	1, 2

- ERV SHALL BE SUPPLIED AS OUTDOOR UNIT.
- ERV SHALL BE VARIABLE AIRFLOW OPERATION.

DIFFUSER & GRILLES SCHEDULE					
MARK	MAKE	MODEL	COUNT	BUILT-IN DAMPER	NOTES
S 1		8/24X24/SPD/31/B12	7		
S 2		8/24X24/SPD/31/B12	7		1
S 3		10/24x24/SPD/31/B12	2		1
S 4		12X6/520/F/LA/B12	6	OPPOSED BLADE DAMPER	1
S 5		18X6/520/F/LA/B12	12	NONE	1
S 6		10X6/520/F/LA/B12	5	NONE	1
R 1		6X6/80/F/A/B12	27		
R 2		8X8/80/F/A/B12	12		
R 3		18X18/80/F/A/B12	3		
R 4		24X24/80/F/A/B12	2		2
R 5		8X4/530/F/LA/B12	2	NONE	
R 6		12X6/530/F/LA/B12	1	NONE	1

- COORDINATE FINISH WITH ARCHITECT.
- PAINT EGG CRATE GRILLE BLACK. CONFIRM WITH THE ARCHITECT.

LOUVER SCHEDULE											
MARK	MANUFACTURER	MODEL	WIDTH		HEIGHT		MAXIMUM RATED AIRFLOW		MAXIMUM ALLOWABLE PRESSURE DROP		NOTES
			in	mm	in	mm	CFM	L/s	0.1 in-wg	Yes	
L 1	PRICE	DE635	48"	1220	66"	1680	6900 CFM	3256	0.12 in-wg	Yes	1
L 2	PRICE	DE635	48"	1220	66"	1680	6900 CFM	3256	0.12 in-wg	Yes	1
L 3	PRICE	DE635	48"	1220	66"	1680	6900 CFM	3256	0.12 in-wg	Yes	1
L 4	PRICE	DE635	20"	510	36"	910	3400 CFM	1605	0.12 in-wg	Yes	1

- LOUVER COMPLETE WITH 1/2" BIRD SCREEN AND MOTORIZED DAMPER. FACTORY BAKED ENAMEL FINISH. COORDINATE COLOUR WITH THE ARCHITECT.

ROOF VENT SCHEDULE														
MARK	MANUFACTURER	MODEL	THROAT WIDTH		THROAT LENGTH		MAXIMUM RATED AIRFLOW		MAXIMUM PRESSURE DROP	DUCTED	CURB HEIGHT	MATERIAL	SHIPS KNOCKED DOWN	ACCESSORIES
			in	mm	in	mm	CFM	L/s						
RV 1	GREENHECK	FGR-24X36	24"	610	36"	914	2490	0.11 in-wg	Yes	18"	GALVANIZED STEEL	YES		
RV 2	GREENHECK	FGR-24X60	24"	610	60"	1524	8796	0.11 in-wg	Yes	18"	GALVANIZED STEEL	YES		
RV 3	GREENHECK	FGR-12X18	12"	305	18"	457	1319	0.11 in-wg	Yes	18"	GALVANIZED STEEL	YES		
RV 5	GREENHECK	FGI-14X24	14"	356	24"	610	2215	0.12 in-wg	Yes	18"	GALVANIZED STEEL	YES		
RV 6	GREENHECK	FGR-14X30	14"	356	30"	762	2565	0.11 in-wg	Yes	18"	GALVANIZED STEEL	YES		
RV 7	GREENHECK	FGI-20X48	20"	508	48"	1219	6330	0.12 in-wg	Yes	18"	GALVANIZED STEEL	YES		

ROOF TOP UNIT SCHEDULE																							
MARK	MAKE	MODEL	ZONE SERVED	SUPPLY AIRFLOW		SUPPLY FAN E.S.P.		SUPPLY FAN POWER		MINIMUM O/A		HEAT OUTPUT		FILTERS	COOLING CAPACITY			ELECTRICAL		MAXIMUM WEIGHT		NOTES	
				(cfm)	(L/s)	("w.c.)	(Pa)	(hp)	(kW)	(cfm)	(L/s)	(%)	(Btu/h)		Total (Btu/h)	Total (tons)	Sen. (Btu/h)	Sen. (tons)	VOLTAGE	PHASE	(lbs)		(kg)
RTU 1	CARRIER	48GCTM08A15A-0A0A0	GYM	2000	944	1.50	373	0.70	0.52	360	170	18.0	96000	THROWAWAY	64110	5.3	45880	3.6	208 V	3	688	312	

- PROVIDE BACNET CONTROLS INTERFACE TO CONNECT TO BUILDING CONTROLS SYSTEM.

SILENCER SCHEDULE																											
MARK	MAKE	MODEL	SERVES	DESIGN AIR VOLUME		DESIGN AIR VELOCITY		FLOW DIRECTION	DESIGN PRESSURE DROP		W		H		L1		L2		Insertion Loss (dB)								NOTES
				(cfm)	(L/s)	(fpm)	(m/s)		(in-wg)	(Pa)	(in)	(mm)	(in)	(mm)	(in)	(mm)	(in)	(mm)	63 Hz	125 Hz	250 Hz	500 Hz	1000 Hz	2000 Hz	4000 Hz	8000 Hz	
SL 1.1	Price	RM58XB	AHU-1	7600	3587	986	5.01	SUPPLY	0.10	24.88	42	1067	32	2'- 8"	58	4'- 10"	0	0'- 0"	8	11	13	19	14	12	10	9	
SL 1.2	Price	ERM74/5A	AHU-1	7600	3587	986	5.01	RETURN	0.20	49.77	42	1067	20	1'- 8"	58	4'- 10"	58	4'- 10"	10	14	21	30	34	30	26	22	
SL 2.1	Price	RM36/4B	AHU-2	2750	1298	1100	5.59	SUPPLY	0.08	19.91	20	508	18	1'- 6"	36	3'- 0"	0	0'- 0"	4	7	11	21	21	16	14	12	
SL 2.2	Price	RM36/4B	AHU-2	2750	1298	1100	5.59	SUPPLY	0.08	19.91	20	508	18	1'- 6"	36	3'- 0"	0	0'- 0"	4	7	11	21	21	16	14	12	
SL 2.3	Price	RM36/5B	AHU-2	2750	1298	1000	5.08	RETURN	0.06	14.93	22	559	18	1'- 6"	36	3'- 0"	0	0'- 0"	5	8	12	21	19	14	12	10	
SL 2.4	Price	RM36/5B	AHU-2	2750	1298	1000	5.08	RETURN	0.06	14.93	22	559	18	1'- 6"	36	3'- 0"	0	0'- 0"	5	8	12	21	19	14	12	10	
SL 3.1	Price	RM36/3B	AHU-3	1100	519	489	2.48	SUPPLY	0.02	4.98	18	457	18	1'- 6"	36	3'- 0"	0	0'- 0"	4	7	11	21	21	16	14	12	
SL 3.2	Price	RM36/3B	AHU-3	1100	519	489	2.48	RETURN	0.02	4.98	18	457	18	1'- 6"	36	3'- 0"	0	0'- 0"	4	8	12	22	22	16	13	11	

PUBLICCITY

Public City Architecture Inc
 11-600 Clifton Street
 Winnipeg, Manitoba
 R3G 2X6 204 475 9323
 publiccityarchitecture.com

Rev. No. Date Revision Notes

0 19-11-06 Issued for Construction



This is a print of a document that has been electronically authenticated with technology authorized by the APEGM. The original is in electronic form.



This drawing must not be scaled. The contractors shall verify all dimensions and other data on site prior to commencement of work. Discrepancies, errors, and omissions are to be reported to Public City Architecture Inc. prior to proceeding with the Work.

Drawings and specifications as instruments of service are the property of Public City Architecture Inc., and when made, must bear their name. All prints to be returned to Public City Architecture Inc. upon request.

Project
ST. JAMES CIVIC CENTRE

Drawing
HVAC SCHEDULES

Drawn By: EB Review By: JS
 Scale: NTS Tender No: 1176-2019
 Date: 11/06/19
 Sheet:

M7.1