

GENERAL NOTES


- A. UPDATE LAMACOID LABELS AND PANEL DIRECTORIES FOR ALL EXISTING PANELS AFFECTED BY THE SCOPE OF WORK (DEMOLITION AND NEW CONSTRUCTION).
- B. FOR ALL EXISTING ELECTRICAL DEVICES, EQUIPMENT, ETC. THAT ARE TO BE REMOVED, REMOVE EXISTING CONDUIT, WIRING, CONTROL PANEL, MOTOR STARTER, ETC. BACK TO SOURCE UNLESS OTHERWISE NOTED. TURN BREAKER OFF. MARK AS SPARE. UPDATE PANEL DIRECTORY AND LABELING. FOR CONDUITS EMBEDDED IN FLOOR SLAB, REMOVE WIRING, CUT CONDUIT AT FLOOR LEVEL, AND SEAL CONDUIT.
- C. EXISTING EQUIPMENT TO BE OFFERED TO THE CITY UPON REMOVAL. DISPOSE OF EQUIPMENT UPON THE CITY'S REQUEST.
- D. COORDINATE WITH THE CITY PRIOR TO SHUT-DOWN OR REMOVAL OF EQUIPMENT.
- E. ALL ABANDONED EQUIPMENT AND SERVICES WITHIN AREA OF WORK SHALL BE REMOVED.
- F. THIS BUILDING MAY CONTAIN ASBESTOS. REFER TO FRONT END SPECIFICATIONS FOR FURTHER INFORMATION.
- G. FIRE STOP ALL PENETRATIONS LEFT BY DEMOLITION OF CABLE/CONDUITS.
- H. ELECTRICAL SUBCONTRACTOR TO VERIFY ALL EXISTING CIRCUITING ON SITE PRIOR TO DISCONNECTION OF LOADS.
- D. CONFIRM ALL EQUIPMENT CONNECTIONS AND ELECTRICAL REQUIREMENTS WITH EQUIPMENT SUPPLIER PRIOR TO ROUGH-IN. MAKE ADJUSTMENTS AND INSTALL AS PER SUPPLIER'S REQUIREMENTS AT NO ADDITIONAL CHARGE.
- E. COORDINATE FINAL LOCATION OF EQUIPMENT WITH MECHANICAL.
- F. THIS BUILDING MAY CONTAIN ASBESTOS. REFER TO FRONT END SPECIFICATIONS FOR FURTHER INFORMATION.

DEMOLITION KEY NOTES [M]

- 1. EXISTING ROLL UP DOOR TO BE REMOVED BY MECHANICAL. DISCONNECT DOOR MOTOR AND ASSOCIATED EQUIPMENT (CONTROLLER, TRAFFIC LIGHT, SENSOR, ETC.). REMOVE WIRE, CONDUIT, ETC. BACK TO SOURCE. EXISTING IN-FLOOR VEHICLE SENSING WIRING TO REMAIN FOR CONNECTION TO NEW DOOR CONTROL PANEL.

KEY NOTES [M]

- 1. WIRE AND CONNECT NEW ROLL-UP DOOR INSTALLED BY MECHANICAL. COORDINATE EXACT LOCATION OF DOOR CONTROL PANEL ON SITE BEFORE ROUGH-IN. CONNECT ALL ASSOCIATED DEVICES/EQUIPMENT (IN-FLOOR SENSOR, TRAFFIC LIGHTS, ETC.). CONNECT EXISTING IN-FLOOR VEHICLE SENSING WIRING TO NEW DOOR CONTROL PANEL. EXTEND WIRING AS REQUIRED USING SOLDERED CONNECTIONS ONLY. COORDINATE WITH MECHANICAL. REFER TO MECHANICAL DRAWINGS AND MOTOR SCHEDULE FOR FURTHER DETAILS.



KEY PLAN
NTS

5			
4			
3			
2			
1			
0	ISSUED FOR CONSTRUCTION	VEK	16/04/19
NO.	Description	BY	DD/MM/YY

ENGINEERS
GEOSCIENTISTS
MANITOBA
Certificate of Authorization
SMS Engineering Ltd.
No. 166



770 Bradford Street
Winnipeg, Canada
T 204 775 0291
SMSeng.com



Project Title
**CITY OF WINNIPEG FORT ROUGE
TRANSIT BASE - RAPID ROLL DOORS
AND RADIANT HEATERS REPLACEMENT**

WINNIPEG MANITOBA

Drawing Title
**MAIN FLOOR PLAN -
MAINTENANCE AND REPAIR
BUILDING - DEMOLITION AND NEW
CONSTRUCTION - ELECTRICAL**

Drawn By	RD	Checked By	RD	Approved By	VEK
Scale	AS SHOWN	Date	APRIL 2019	Project No.	19-028-01
Revision Number	0	Drawing Number	E2.2	Sheet Order	3 OF 4

1 MAIN FLOOR PLAN - MAINTENANCE AND REPAIR BUILDING - DEMOLITION - ELECTRICAL
SCALE: 1/16" = 1'-0"

2 MAIN FLOOR PLAN - MAINTENANCE AND REPAIR BUILDING - NEW CONSTRUCTION - MECHANICAL
SCALE: 1/16" = 1'-0"