



# 338-2019 ADDENDUM 1

## SUPPLY OF PUMPING EQUIPMENT AND VALVES FOR JESSIE WASTEWATER PUMPING STATION UPGRADES

### URGENT

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE  
TENDER**

ISSUED: June 4, 2019  
BY: Blair Moore  
TELEPHONE NO. 204 453-2301

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE TENDER AND SHALL FORM A PART  
OF THE CONTRACT DOCUMENTS**

Template Version: A20190115

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Tender, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Bid may render your Bid non-responsive.**

### PART A – BID SUBMISSION

Replace: 338-2019 Bid Submission with 338-2019 Addendum 1 - Bid Submission. The following is a summary of changes incorporated in the replacement Bid Submission:

Form B(R1): Revised Items No. 4, 5 and 6.

Page numbering on some forms may be changed as a result.

### PART D – SUPPLEMENTAL CONDITIONS

Revise: D2.2 (b)(i) to read: Eight (8) 250 mm gate valves – manually actuated, **non-resilient metal seated**.

Revise: D2.2 (b)(ii) to read: Two (2) 250 mm gate valves – manually actuated, **resilient seated**.

Revise: D2.2 (c)(i) to read: Two (2) 150 mm gate valves – manually actuated, **resilient seated**

Revise: D9.1 to read: Goods shall be delivered by January 6, 2020, f.o.b. destination, freight prepaid to:

Collections Supervisor  
360 McPhillips Street  
Winnipeg, Manitoba R2J 2W7  
(204) 986-4788

### PART E – SPECIFICATIONS

Revise: E2.4 to read: The Contractor shall supply eight (8) 250 mm gate valves, non-resilient metal seated, in accordance with the requirements hereinafter specified.

Revise: E2.5 to read: The Contractor shall supply two (2) 250 mm gate valves, resilient seated, in accordance with the requirements hereinafter specified.

Revise: E2.4 to read: The Contractor shall supply two (2) 150 mm gate valves in accordance with the requirements hereinafter specified.

Add: E3. **EXPEDITED SHOP DRAWINGS**

- Add: E3.1 Further to Specification No. 01 33 00, in order to expedite Shop Drawings with critical timeliness, the lowest responsive Bidder, as outlined in B17, after receiving written approval from the Contract Administrator, to arrange for the preparation of Shop Drawings for the following items with critical timelines.
- a) Three (3) 156 l/s non-clog pumps at approximately 22.6 m Total Dynamic Head, complete with motors, extended drive shafts, guard and all accessories as indicated in E2.1.
  - b) Eight (8) 250 mm gate valves, non-resilient metal seated, as indicated in E2.4.
  - c) Two (2) 250 mm gate valves, resilient seated, as indicated in E2.5.
  - d) Two (2) 150 mm gate valves, resilient seated, as indicated in E2.6.
  - e) Two (2) 500 mm gate valves complete with operators, stem, wall brackets and all other accessories as indicated in E2.8.
  - f) Three (3) 250 mm check valves with “hold-open” device as indicated in E2.9.
- Add: E3.2 If the Contract is awarded, no payment for the preparation of Shop Drawings will be made.
- Add: E3.3 If no contract is awarded, then the City of Winnipeg will pay the requested Bidder up to a maximum of five hundred dollars (\$500.00) for each of the requested submissions noted above, for the preparation and delivery of Shop Drawings. Delivery of the Shop Drawings to the City and payment of the above amounts will constitute full and final consideration of each party to the other, and neither party will have any further liability to the other with respect to this Tender.

## **NMS FORMAT SPECIFICATIONS**

### **Section 40 05 52 – PROCESS VALVES**

- Revise: 1.1.1.1 to read Rising Stem Gate Valves
- .1 Eight (8) 250 mm Gate Valves – manually actuated, non-resilient-metal seated.
  - .2 Two (2) 250 mm Gate Valves – manually actuated, resilient seated.
- Revise: 1.1.1.2 to read Non-Rising Stem Gate Valves
- .1 Two (2) 150 mm Gate Valves – manually actuated, resilient seated.
- Revise: 2.3.5 to read Provide non-resilient metal seated and resilient seated gate valves as specified in D2.
- Revise: 2.3.15 to read Acceptable manufacturers – one of the following:
- .1 American Valve Company
  - .2 Pratt
  - .3 Clow Canada
  - .4 Dezurik
  - .5 Mueller Canada
  - .6 **Kennedy Valves; or**
  - .7 Approved equal in accordance with B7.

Add: 2.3.16 Resilient seated gate valves – The disc shall be precision molded Buna-N (NBR) ASTM D2000-BG. Optional disc material includes Vitob, EPDM, Hypalon, SBR ASTM D2000.

**Section 43 21 13 – CENTRIFUGAL SHAFT PUMPS**

Revise: 2.1.2.2 to read Minimum Shut off Head **35 m**

Revise: 2.1.2.2 to read Diameter of Pump Discharge 250 mm (10")

.1 **Acceptable to supply 150 mm (6") diameter discharge with enlarger to 250 mm (10")**