



473-2019 ADDENDUM 1

SUPPLY AND DELIVERY OF CAST IRON CONTROL GATES FOR BURROWS OUTFALL GATE CHAMBER UPGRADES

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: May 21, 2019
BY: Mark Baker, P.Eng.
TELEPHONE NO. 204 688-3805

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Add: E2.5: The design of the revised structure is scheduled for completion in the summer of 2019. For the purpose of bidding this contract, the gate thimbles are to be 304mm.

DRAWINGS

Add: 473-2019_Drawing_SC15925 Details of Burrows Ave. Storm Relief Gate Chamber - Revised As Constructed - 1971