



- NOTES:**
1. CONTRACTOR SHALL COORDINATE TEMPERATURE ALARM TERMINATION POINTS IN THE RTU WITH THE CITY.
 2. CONTRACTOR SHALL PROVIDE AND INSTALL A 2-POLE TEMPERATURE SWITCH. HIGH TEMPERATURE SET POINT SHALL BE 30°C. LOW TEMPERATURE SET POINT SHALL BE 10°C.

LEGEND:

--- FIELD WIRING

— MANUFACTURER WIRING

**ENGINEERS
GEOSCIENTISTS
MANITOBA**

Certificate of Authorization

KGS Group

No. 245

KGS GROUP CONSULTING ENGINEERS					ENGINEER'S SEAL	
					DESIGNED BY: L. UPPAL	CHECKED BY: J. BOUCHARD
					DRAWN BY: J. deLEON	APPROVED BY: J. BOUCHARD
					SCALE: AS NOTED	DATE: 2019/07/12
					RELEASED FOR CONSTRUCTION	
					BY:	DATE:
					CONSULTANT NO.: 19-0107-002_E21	
00	ISSUED FOR TENDER AND CONSTRUCTION	2019/07/12	LU	JAB		
NO.	REVISIONS	DATE	DESIGN	CHECK		

THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT

CLIFTON FLOOD PUMPING STATION UPGRADES

**ELECTRICAL
TEMPERATURE SWITCH TS-F620
LOOP DIAGRAM**

CITY DRAWING NUMBER 1-0125F-E0027-001	SHEET	REV. 00	SIZE B
---	-------	-------------------	------------------