



845-2019 ADDENDUM 1

SUPPLY AND INSTALLATION OF SECURITY COMPONENTS FOR 552 PLINGUET AND 598 PLINGUET

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
TENDER**

ISSUED: November 22, 2019
BY: Dave Murdoch
TELEPHONE NO. 204 986-7577

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE TENDER AND SHALL FORM A PART
OF THE CONTRACT DOCUMENTS**

Template Version: A20190115

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Tender, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

- Revise: D2.2(b)(ii) to read: **Connect Emergency Dispatch and Administration Desk Command control desk (C-EE980) to Cisco WS-C2960X-24PD-L through Cat6 cable in server room. The cable shall be run in 3/4" EMT. The distance from the C-EE980 at the Administration desk to the 2960 Cisco switch in the Server Room is 90'; the Emergency dispatch C-EE980 is 25' from the server room.**
- Revise: D2.2(b)(iii) to read: **Connect 598 Stores Command Control Desk (C-EE980) to Cisco WS-C2960X-24PD-L through Cat6 cable in stores network area. The cable shall be run in 3/4" EMT. The distance from the Command Control Desk to the 2960 POE Switch located in the 598 stores building is 33'.**
- Revise: D2.2(b)(iv) to read: **Connect 552 Stoers Command Control Desk (C-EE980) to Cisco WS-C2960X-24PD-L through Cat6 cable in Utility closet network rack. The cable shall be run 3/4" EMT. The distance from the C-EE980 on the 552 Stores counter (south building) to the 2960 POE switch located in the Utility Closet (south building) is 60'.**
- Revise: D2.2(d)(i) to read: **Install one (1) Omni mount RE12 W in 598 equipment shed (location to be determined at site visit). Mount one power outlet inside the RE12W. Run power to the outlet from the breaker panel in the same building. In addition the City will supply a Cisco 2960 POE switch providing power for the two (2) LP1501.**
- Revise: D2.2(g) to read: **Except for items put into use with the City's permission, leave date of beginning of time of warranty until Date of Total Performance is determined.**