



163-2020 ADDENDUM 2

ARLINGTON OVERPASS (CPR YARDS) – 2020 STRUCTURAL STEEL REPAIRS

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE TENDER

ISSUED: May 15, 2020
BY: Mohamed Mady
TELEPHONE NO. 204 986-4046

THIS ADDENDUM SHALL BE INCORPORATED INTO THE TENDER AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20190115

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Tender, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: E4.2.4 (a) to read:

- (a) All existing steel surfaces, **except steel decking**, receiving new steel shall be cleaned by blast cleaning to a minimum of SSPC-SP 7 (Brush-off Blast Cleaning) to remove excess oil, dirt, rust, and other debris to the satisfaction of the Contract Administrator.

Revise: E4.3.6 (b) to read:

- (b) Corrugated steel decking shall be 1.22mm thick with 38mm flute depth as shown on the Drawings. Approved products are CD36 from AGWAY, P-3606 from CANAM, or equivalent as accepted by the Contract Administrator.

DRAWINGS

Replace: 163-2020_Drawing_B106-20-07_R0 with 163-2020_Addendum_2_Drawing_B106-20-07_R1