

PUMP SCHEDULE

NO.	LOCATION	MAKE	MODEL	PUMP SERVICE	PUMP TYPE	SIZE IN. X IN. X IN. (mm X mm X mm)	FLOW GPM (l/s)	HP	FLUID TYPE	THERMOFLUID		HEAD FT (PSI)	SPEED RPM	UNIT WEIGHT LBS (KG)	CONTROLS						FLA	MCA	MOCP	POWER						STARTER						REMARKS				
										YIN	%				TYPE	INTERLOCK			F.A. SHUT DOWN	DATA CONN.				NOTES	PANEL	EM	VIO	FEEDER	COND	BRKR	CCT	TYPE	SUPPLY	INSTALL	FUNC		PL	PB	HOA	
																SUPPLY	INSTALL	WITH																						
P-1	DRY PIT	--	--	PRIMARY FOUNTAIN	HORIZONTAL BASE-MOUNT	-- (-)	400 (-)	20	WATER			20 (-)	--	-- (-)	MEDH	MEDH	VSD	NO	NO	--		59.4	75	100	NO (-)	208V/3P	3 #4 THD#0	--	100A/3P	A-1,2,3	VSD	MEDH/MCAL	*MOUNTING E-WIRING							ELECTRICAL CONTRACTOR SHALL UTILIZE VSD RATED CABLING FOR FINAL CONNECTION TO MOTOR. COORDINATE REQUIREMENTS WITH MANUFACTURER'S RECOMMENDATIONS.



LOCATIONS APPROVED UNDERGROUND STRUCTURES

SIGNED BY: _____ DATE: _____

SURV U/G STRUCTURES DATE

LOCATION OF UNDERGROUND STRUCTURES AS SHOWN ARE BASED ON THE BEST INFORMATION AVAILABLE BUT NO GUARANTEE IS GIVEN THAT ALL EXISTING UTILITIES ARE SHOWN OR THAT THE GIVEN LOCATIONS ARE EXACT CONFIRMATION OF EXISTENCE AND EXACT LOCATION OF ALL SERVICES MUST BE OBTAINED FROM THE INDIVIDUAL UTILITIES BEFORE PROCEEDING

G.B.M. -	BENCHMARK LOCATION
ELEV. 232.xxx	TOP OF TOP NUT ON HYDRANT
H	
G	
F	
E	
D	
C	
B	
A	ISSUED FOR CONSTRUCTION
NO.	REVISIONS

12853

DESIGNED BY: DCJ/MJB
DRAWN BY: SM/MJB

CHECKED BY: DCJ/MJB
APPROVED BY: DCJ/MJB

HR. SCALE: VERTICAL
RELEASED FOR CONSTRUCTION

DATE: 2020-04-15



MECHANICAL ONLY

ELECTRICAL ONLY

ENGINEER'S SEAL

CONSULTANT ACAD DWG. NO. ME.1

THE CITY OF WINNIPEG
PLANNING, PROPERTY & DEVELOPMENT DEPARTMENT
PLANNING & URBAN DESIGN DIVISION

BROADWAY FOUNTAIN REFURBISHMENT

MECHANICAL / ELECTRICAL SCHEDULES

CITY DRAWING NUMBER
SHEET 4 OF 4
BID NO. 250-2020