



ARENA CRAWLSPACE - HVAC
SCALE: 3/32" = 1'-0"

KEY NOTES

1. PROVIDE TEMPERATURE AND HUMIDITY SENSORS IN CRAWLSPACE. CONNECT TO MAIN BUILDING DDC FOR MONITORING AND CONTROL.
2. NEW CIRCULATION FAN SHALL BE SUSPENDED FROM UNDERSIDE OF SLAB.
3. PROVIDE OPENING FROM STORAGE ROOM TO CRAWLSPACE COMPLETE WITH MOTORIZED DAMPER.
4. PROVIDE TEMPERATURE SENSOR IN DISCHARGE AIR DUCTWORK FOR CONTROL OF CU-1.
5. PROVIDE DX COOLING COIL IN DUCTWORK SUPPLYING CRAWLSPACE. PROVIDE STAINLESS DRAIN PAN, ROUTE CONDENSATE DRAIN TO NEAREST SLUMP PIT.
6. DUCT TO CRAWLSPACE. ROUTE BENEATH BLEACHERS AND UNDER SLAB. USE EXISTING OPENING TO PASS THROUGH WALL NEXT TO NEW ACCESS HATCH. COORDINATE WITH STRUCTURAL AND ARCHITECTURAL.
7. ROUTE NEW DUCTWORK IN SAME LOCATION AS EXISTING.

KEY PLAN
NTS

The General Contractor shall check & verify all dimensions and report any errors or omissions to the designers.

0	2020-10-30	ISSUED FOR CONSTRUCTION
---	------------	-------------------------

Certificate of Authorization
Epp Siepman Engineering Inc.
No. 4035

Consultant

400 - 136 Market Avenue
Winnipeg, MB R3B 0P4
T 204.943.1080

300-275 Carlton Street
Winnipeg, Manitoba R3C 5R6
T 204.943.7501
F 204.943.7507

Crosier Kilgour & Partners Ltd.
CONSULTING STRUCTURAL ENGINEERS

Project

SJCC RINK CRAWLSPACE

ARENA CRAWLSPACE RESTORATION

2055 NESS AVENUE
WINNIPEG, MANITOBA

Sheet Title

ARENA CRAWLSPACE - HVAC PLAN

File	20057	Date	2020-09-17
Design	JS	Drawn	DK
Revision	Sheet No.		

MH2.1