



- KEY NOTES**
1. PROVIDE DRY SPRINKLER ZONE TO SERVE ARENA CRAWLSPACE. CONNECTED TO SPRINKLER TREE IN BASEMENT INCOMING SERVICES ROOM.
 2. ROUTING FOR MAIN ELECTRICAL FEEDERS SHOWN FOR REFERENCE. FEEDERS ARE TO BE PROTECTED DURING CONSTRUCTION AND AVOIDED WHERE POSSIBLE.

SPRINKLER COVERAGE SCHEDULE								
SPACE			AREA	HAZARD LEVEL	TYPE	SPRINKLER HEAD		OBSTRUCTED / UNOBSTRUCTED
NUMBER	NAME	LEVEL				ORIENTATION	SERVICE CONDITION	
1	CRAWLSPACE	0-Basement/Crawlspace	21701 SF	Light			Dry	
2	Space	Not Placed	Not Placed	Light			Dry	
3	Space	0-Basement/Crawlspace	1551 SF	Light			Dry	
4	EXTERIOR	1-Main	24 SF					

KEY PLAN
NTS

The General Contractor shall check & verify all dimensions and report any errors or omissions to the designers.

0	2020-10-30	ISSUED FOR CONSTRUCTION
---	------------	-------------------------

Certificate of Authorization
Epp Siepman Engineering Inc.
No. 4035

Consultant

400 - 136 Market Avenue
Winnipeg, MB R3B 0P4
T 204.453.1080

Crosier Kilgour & Partners Ltd.
CONSULTING STRUCTURAL ENGINEERS

Project

SJCC RINK CRAWLSPACE

ARENA CRAWLSPACE RESTORATION

2055 NESS AVENUE
WINNIPEG, MANITOBA

Sheet Title

ARENA CRAWLSPACE - FIRE PROTECTION PLAN

File	20057	Date	2020-09-17
Design	JS	Drawn	DK
Revision	Sheet No.		

MF2.1