

 PARTIAL REFLECTED CEILING PLAN - RENOVATION
SCALE: 1/4"=1'-0"

- ELECTRICAL RENOVATION NOTES:** "X"
- ALSO SEE NOTES & SPECIFICATIONS.
ALL WIRING & CABLING IN CEILING SPACE SHALL BE PLENUM RATED AS PER LATEST CEC.
IF REQUIRED, PROVIDE WIRE, CONDUIT, END-OF-LINE RESISTORS & BOOSTER POWER SUPPLIES.
- PROVIDE EMERGENCY BATTERY BANK 2-HEAD UNIT.
 - WIRE TO MONITOR LIGHTING CIRCUITS IN SEWING ROOM & LAUNDRY ROOM WITH REQUIRED ZONE SENSING RELAY TO ACTIVATE 2-HEAD REMOTE EMERGENCY LAMPS UPON LOSS OF POWER.
 - PROVIDE NEW SMOKE DETECTORS. WIRE TO EXISTING SYSTEM.
 - PROVIDE NEW HORN/STROBE WITH END OF LINE (EOL) RESISTOR. CONNECT TO EXISTING CIRCUIT. MOUNT HORN STROBE 96" AFF.


EMERGENCY SIGN AND LIGHTING SCHEDULE					
TAG	DESCRIPTION	MANUFACTURER	CATALOG No.	VOLTS	BRANCH CIRCUIT
EBB-1	BATTERY UNIT W/ 2-LAMP	AIMLITE	EBST06036-2MB-4WLR-WHT	120/347VAC	AS SHOWN, WIRE WITH VSR

NOTES:


REFER TO DRAWING E1.

INSTALLATION SHALL BE IN CONFORMANCE WITH CANULC-S524-M, STANDARD FOR INSTALLATION OF FIRE ALARM SYSTEMS. NOTIFY BUILDING OWNER PRIOR TO PERFORMING A MANDATORY FIRE ALARM VERIFICATION REPORT IN CONFORMANCE WITH CANULC-S537, STANDARD FOR VERIFICATION OF FIRE ALARM SYSTEMS FOR ZONES AFFECTED.

0	ISSUED FOR CONSTRUCTION	DTA	2020-09-30
No.	REVISION/DESCRIPTION	BY	DATE



DRAWN	CHECKED	DESIGNED	APPROVED
DATE: 2020-09-15	USER APPROVAL		

 THE CITY OF WINNIPEG
PLANNING, PROPERTY AND
DEVELOPMENT DEPARTMENT
MUNICIPAL ACCOMMODATIONS DIVISION
3-65 GARRY STREET, R3C 4K4

PROJECT
FPS TRAINING, REPAIR & STORAGE FACILITY
TURN OUT GEAR LAUNDRY ROOM

2546 McPhillips Street
2546 McPhillips Street
BID OPP: 696-2020

SHEET TITLE
PARTIAL MAIN FLOOR REFLECTED CEILING PLAN
ELECTRICAL
FIRE ALARM AND EMERGENCY LIGHTING

SCALE	PROJECT No:	SHEET No:
AS SHOWN	2020-047	E3