

## 711-2020 ADDENDUM 2

## SUPPLY AND DELIVERY OF NEW MOBILE DIESEL GENERATOR

## **URGENT**

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE TENDER

ISSUED: October 13, 2020 BY: Whitney Morse TELEPHONE NO. 204 619-4852

THIS ADDENDUM SHALL BE INCORPORATED INTO THE TENDER AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Tender, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Bid may render your Bid non-responsive.

## PART E - SPECIFICATIONS

Revise: E2.2.2 (c) to read: Meets all applicable Government emission standards.

Revise: E2.2.7 (a) to read: Max noise of 75dB(A) @ 7 m (23 ft.)

Revise: E2.2.9 to read: Approved Manufacturers

a) Kohler

- b) Caterpillar
- c) Cummins
- d) Generac
- e) Wacker Neuson
- f) Atlas Copco