



728-2020 ADDENDUM 1

CITY OF WINNIPEG DOWNTOWN PAVEMENT RENEWALS 2021: DONALD STREET, HARGRAVE STREET

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
TENDER**

ISSUED: December 11, 2020
BY: Thomas Findlay
TELEPHONE NO. 204 390-1464

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE TENDER AND SHALL FORM A PART
OF THE CONTRACT DOCUMENTS**

Template Version: A20190115

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Tender, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

QUESTIONS AND ANSWERS

- Q1: Consideration for the use of precast bases as a substitute for the cast in place bases which are equivalent to the City of Winnipeg SD-312A (type OD) and SD-313 (type G base), considering that these bases have been previously used on City of Winnipeg street renewal projects in 2020.
- A1: Precast signals bases may be considered as an approved alternative upon award of the contract with approval by the Contract Administrator, provided that the bases have been deemed structurally and functionally equivalent by a 3rd party engineering review and pending approval of City of Winnipeg Traffic Services. Precast bases must match the dimension for the cast in place bases close enough that there are not any conflicts with the proposed layout of the signals bases. If conflicts arise due to the difference in size, then cast in place bases will be required.