



904-2020 ADDENDUM 2

RINK BOARD TEMPERED GLASS & SPECTATOR SAFETY NETTING REPLACEMENT – GLENWOOD COMMUNITY CENTRE – 75 OVERTON STREET

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: February 10, 2021
BY: John Atkinson
TELEPHONE NO. 204 794-4418

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: A20190115

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, February 16, 2020

PART D – SUPPLEMENTAL CONDITIONS

Revise: D12.1 to read: The Contractor shall achieve Substantial Performance by May 7, 2021.

Revise: D13.1 to read: The Contractor shall achieve Total Performance by May 31, 2021.

QUESTIONS AND ANSWERS

Q1: Is the ice being left in during the project?

A1: No. The ice has been removed and will remain out during construction.

Q2: What is the width of the top sill?

A2: The top sill plate is 8 inches in width.

Q3: What is the width of the sill band?

A3: The sill band is 1 1/2 inches in width.

Q4: Height to bottom of roof trusses?

A4: The height of roof trusses from the sill plate to underside of roof trusses is 13' 3".

The height to roof trusses at centre rink from floor slab is 20' 8".

Q5: Do you have a shop drawing of the existing boards? I am specifically looking for the glazing lengths on the players box side (areas without glazing).

A5: The City does not have shop drawing of the existing boards. The area without glazing on the players box side is 68' 6" less time keeper's box of 5' 7"

Q6. The document states that award date is March 31, 2021, substantial 5 days later on April 5th and final completion on April 30, 2021. Are these dates accurate?

A6: Substantial Performance and Total Performance dates have been revised:

The Contractor shall achieve Substantial Performance by May 7, 2021.

The Contractor shall achieve Total Performance by May 31, 2021.