

19-2021 ADDENDUM 01

POOL TANK ROOF REPLACEMENT MARGARET GRANT POOL 685 DALHOUSIE

ISSUED: Jan 14, 2021 BY: David Firth

TELEPHONE NO. 204 451-4098

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID/PROPOSAL

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID/PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART E - SPECIFICATIONS

Revise: E1.5.4 to read: VAPOUR BARRIER

(a) This shall be 1 ply Soprema Elastophene Flam 2.2 or IKO Torchflex TF-95-FF base 2.2mm followed by a second ply of Soprema Elastophene S/P or IKO Torchfflex TF-95-SF-Base 2.2mm or approved equal in accordance with B7.

Revise: E1.5.5 to read: ROOFING INSULATION

(a) Soprema Sopra-ISO Plus 25 psi polyisocyanurate insulation with acrylic facer or IKO – IKOTherm III 25 psi polyisocyanurate insulation or approved equal in accordance with B7. Thickness is as indicated on the roof plan.

Revise: E1.5.8 to read: MODIFIED BITUMEN MEMBRANE

- (a) Picture framing 3' minimum:
 - (i) Soprema Sopralene Stick HR 40 base or IKO Armourstick TP-HD for the base layer and Soprema Sopralene Stick HR GR or IKO Armourstick TP-HD for the cap sheet or approved equal in accordance with B7, is to be used for a minimum distance of 3' around all curbed openings and perimeter edges as well as for stripping. Use in conjunction with manufacturers recommended primer and adhesive. Install in strict accordance to the manufacturer's guidelines.
- (b) Main Field Membrane:
 - (i) Soprema Colvent 830 or IKO Armourbond Flash self-adhering base sheet for the 2-ply base layerwith a Soprema Colvent 860 or IKO Torchflex TP-HD for the cap sheet (heavy traffic) or approved equal in accordance with B7.
- (c) Stripping:
 - (i) Soprema Sopralene Stick HR 40 base or IKO Armourstick TP-HD for the base layer and Soprema Sopralene Stick HR GR or IKO Armourstick TP-HD for the cap sheet or approved equal in accordance with B7.

Delete: E1.6.24 Membrane manufacturer 10 year membrane warranty (Mammouth Plus) is to be provided.

Tender No. 19-2021 Addendum 01 Page 2 of 2

E1.7.30

Delete:

A new access ladder is to be installed to replace the existing up to area A2. The ladder is to incorporate a protective cage if over 12' in height or as indicated by local safety regulations. Engineer approved shop drawings are to be submitted for approval prior to fabrication and installation. The ladders are to be permanently wall mounted in a structurally sound manner. Ladders are to be fabricated in a similar manner as detailed. Ladders are to be hot dipped galvanized.