



305-2021 ADDENDUM 1

ROOF REPLACEMENT – OSBORNE LIBRARY AND LINK ROOF - 625 OSBORNE

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: May 10, 2021
BY: David Firth
TELEPHONE NO. 204 451-4098

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: A20190115

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART B - BIDDING PROCEDURES

Revise B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, May 13, 2021.

QUESTIONS AND ANSWERS

Q1: What is the new roof assembly

A1: Roof assembly is to provide a minimum effective R30. Top layer(s) to be Polyiso insulation with underlying tapered EPS Type II insulation as required.