



GENERAL NOTES

- ALL ABANDONED EQUIPMENT AND SERVICES WITHIN AREA OF WORK SHALL BE REMOVED.
- B. THIS BUILDING MAY CONTAIN ASBESTOS. REFER TO FRONT END SPECIFICATIONS FOR FURTHER INFORMATION.
- C. REFER TO ROOF DETAILS AND SPECIFICATIONS FOR ALL NEW AND CAPPED OPENINGS.
- D. FOR DRAWING CLARITY, NOT ALL MECHANICAL EQUIPMENT, PIPING AND DUCTWORK HAS BEEN SHOWN.

KEY NOTES ₩

- 1. INSTALL FLUE VENT IN ACCORDANCE WITH MANUFACTURER REQUIREMENTS. PROVIDE WEATHER TIGHT SEAL IN ACCORDANCE WITH ROOF DETAIL AND MATCH THE CONSTRUCTION AND FINISH FROM ADJACENT CONDITION. CONTRACTOR TO CONFIRM EXACT LOCATION ON SITE.
- COMBUSTION AIR INTAKE THROUGH ROOF, PROVIDE WEATHER
 TIGHT SEAL IN ACCORDANCE WITH ROOF DETAIL AND MATCH THE
 CONSTRUCTION AND FINISH FROM ADJACENT CONDITION.
 CONTRACTOR TO CONFIRM EXACT LOCATION ON SITE.
- 3. REINSTALL EXISTING ROOF DRAIN AND OFFSET RWL. SLOPE ROOF TO NEW ROOF DRAIN LOCATION.
- 4. NEW ROOF HYDRANT LOCATED BESIDE HRU. COORDINATE FINAL LOCATION ON SITE.
- 5. NEW HRU. REFER TO M4.2 FOR FURTHER INFORMATION.
- 6. PROVIDE CONDENSATE DRAIN TO DISCHARGE ONTO ROOF C/W HEAT TRACE (BY ELECTRICAL) AND INSULATION.
- 7. PROVIDE NEW NATURAL GAS TO NEW HRU.
- 8. RELOCATE PRV VENT THROUGH ROOF. PROVIDE WEATHER TIGHT SEAL. CONTRACTOR TO CONFIRM THE EXACT LOCATION ON SITE.









J. T. HORROCKS Member 24767

MANITOBA



Project Title

WINNIPEG

TRANSIT MAINTENANCE AND REPAIR BUILDING MECHANICAL UPGRADE - WEST HIGH BAY

PARTIAL ROOF PLAN PLUMBING NEW CONSTRUCTION

0	M2.2	7 OF 10
Revision Number	Drawing Number	Sheet Order
Scale 1/16"=1'-0"	Date JUNE 2022	Project No. 20-349-01
RNS	XZ	JH
Drawn By	Checked By	Approved By