

**INSTALLATION DETAILS FOR
POSITIVE DISPLACEMENT AND
NON-MECHANICAL TYPE WATER METER
IN BUILDINGS
20mm & 25mm DOMESTIC SERVICE PIPE**

METER SIZE	A (mm)
16mm (5/8")	318
20mm (3/4")	362
25mm (1")	413

NOTES:

- 1) THE SERVICE PIPE MUST ENTER A BUILDING A MINIMUM OF 300mm AND A MAXIMUM OF 1000mm FROM THE EXTERIOR WALL
- 2) PIPE SUPPORT / ANCHORING MUST BE PROVIDED TO MAINTAIN PIPE ALIGNMENT AND TO SUPPORT THE WEIGHT OF THE PIPE, METER AND RELATED COMPONENTS
- 3) METERS MUST BE INSTALLED IN A HORIZONTAL POSITION
- 4) COPPER TO FEMALE IRON PIPE THREAD ADAPTORS MUST BE SUPPLIED TO ACCOMMODATE METER TAILPIECES
- 5) THE CONTROL AND OUTLET VALVE MUST BE FULL PORT GATE OR BALL VALVES
- 6) NO CONNECTIONS ARE PERMITTED UPSTREAM OF THE WATER METER
- 7) APPROVED BACKFLOW PREVENTION DEVICE, AS REQUIRED, IN ACCORDANCE WITH THE NATIONAL PLUMBING CODE (SPECIFIC HEIGHT REQUIREMENTS EXIST FOR BACKFLOW DEVICES WHICH DIFFER FROM THOSE SHOWN ON DRAWING)
- 8) WATER METERS MUST NOT BE INSTALLED IN CONFINED SPACES (EG. CRAWL SPACES). WHERE A SERVICE PIPE ENTERS A CONFINED SPACE THE WATER METER MUST BE INSTALLED IN THE IMMEDIATE ADJACENT SPACE INTENDED FOR CONTINUOUS OCCUPANCY. ALL WATER SERVICE PIPE ENTERING THE BUILDING TO THE WATER METER MUST BE CLEARLY VISIBLE FROM THE WATER METER WITHOUT ENTRY TO THE CONFINED SPACE (EG. ACCESS DOOR)

RECOMMENDATIONS:

- 1) METER TO BE INSTALLED IN CLOSE PROXIMITY TO FLOOR DRAIN ON AN UNFINISHED FLOOR
- 2) PROVIDING UNOBSTRUCTED SPACE OF 1000mm WIDE BY 1000mm DEEP BY 2000mm HIGH, CENTERED IN FRONT OF THE WATER METER, WILL BE DEEMED COMPLIANT WITH THE ACCESS REQUIREMENTS OF THE WATER BY-LAW



**THE CITY OF WINNIPEG
WATER & WASTE DEPARTMENT**

Reference Spec. No.

**INSTALLATION DETAILS FOR
POSITIVE DISPLACEMENT AND
NON-MECHANICAL TYPE WATER METER
IN BUILDINGS
20mm & 25mm DOMESTIC SERVICE PIPE**

Designed By:
JCE

Drawn By:
TV

Scale:

N.T.S.

Checked By:
WATER BY-LAW
COMMITTEE

Date: 2016-03-16

Revision: 9

Drawing No.

SD-027B (2 of 2)

Approved:
WATER BY-LAW COMMITTEE