


CCTV SPECIFICATIONS

- 1 ELECTRICAL CONTRACTOR TO SUPPLY & INSTALL EMT CONDUITS, JUNCTION BOXES, & SUPPLY & INSTALL CAT6 CABLES FOR THE CCTV SYSTEM. TERMINATE & TEST WIRES. KEEP TEST LOG & INCLUDED IN O&M MANUAL. CONTACT MR. MICHEAL KUCBEL- BUILDING SYSTEM TECHNICIAN AT THE CITY OF WINNIPEG IN THE MUNICIPAL ACCOMMODATIONS TO OBTAIN LIST OF MATERIAL (& EQUIPMENT) DESIGNATED FOR THIS PROJECT. ELECTRICAL CONTRACTOR TO INCLUDE COST FOR THE INSTALLATION OF THE CCTV COMPONENTS & COMMISSIONING OF THE SYSTEM TO CITY OF WINNIPEG SATISFACTION. CCTV SYSTEM IS LOCATED AT SECOND LEVEL MECH. ROOM.

CCTV LEGEND



PANIC/ DISTRESS ALARM SYSTEM

- 1 ELECTRICAL CONTRACTOR TO SUPPLY & INSTALL EMT CONDUITS, JUNCTION BOXES, & SUPPLY & INSTALL REQUIRED CABLES FOR THE PANIC/ DISTRESS ALARM SYSTEM AS SPECIFIED.
- 2 DISTRESS SYSTEM SHALL COMPRISE OF
 1- PANIC BUTTON: NO MOVING PARTS, STAINLESS STEEL COVER PLATE C/W VANDAL PROOF HARDWARE, WIRED SYSTEM. ENGRAVED TEXT ABOVE BUTTONS TO READ "ACTIVATE TO CALL ALARM IN CASE OF NEED. ALARM WILL SOUND".
 2- STROBE LIGHT: VANDAL PROOF HARDWARE INSTALLED TO ORDINARY RECESSED BOX C/W VANDAL PROOF HARDWARE, WIRED SYSTEM.
 3- HORN/SIREN: TEMPORAL SIGNAL OUTPUT.
 4- MAIN SYSTEM: TO BE HARDWIRED TO ABOVE DEVICES, ACTIVATION OF PARTICULAR PANIC BUTTON WILL ACTIVATE SELECTIVE STROBE LIGHT & HORN/SIREN C/W LOG FOR LOGGING CAPABILITY TO SAVE & RETAIN EVENTS FOR 12 MONTHS.

PANIC/ DISTRESS ALARM SYSTEM LEGEND

+ ①	PANIC BUTTON, STAINLESS STEEL PLATE WITH NO MOVING PART. INSTALLED AT 30" AFFL.
+ ②	DISTRESS SYSTEM STROBE LIGHT, 70cd. BLUE LIGHT COLOR INSTALL AT 7' AFFL.
+ ③	DISTRESS SYSTEM HORN/SIREN, 100dB, OUTDOOR RATED, RED COLOR INSTALL AT 9' AFFL.
DIS	PANIC/ DISTRESS MAIN SYSTEM - INSTALL AT SECOND LEVEL MECH. ROOM

INTRUSION ALARM

NOTE: PROVIDE INDENT IN CONC SIDWALK AT...
 ELECTRICAL CONTRACTOR TO SUPPLY & INSTALL EMT CONDUITS, JUNCTION BOXES, & SUPPLY & INSTALL CAT3 CABLES FOR INTRUSION ALARM SYSTEM. TERMINATE & TEST WIRES. KEEP TEST LOG & INCLUDED IN O&M MANUAL. SUPPLY & INSTALL TERMINATION POINTS FOR DOOR CONTACTS FOR THE TWO MAIN DOORS & OFFICE DOOR. KEYPAD TO BE WALL MOUNTED IN OFFICE, SYSTEM IN SECOND LEVEL. SYSTEM TO BE MONITORED TO CITY'S CENTRAL SYSTEMS. CONTACT MR. MICHEAL KUCBEL- BUILDING SYSTEM TECHNICIAN AT THE CITY OF WINNIPEG IN THE MUNICIPAL ACCOMMODATIONS TO OBTAIN APPROVED LIST OF EQUIPMENT SUPPLIERS. ELECTRICAL CONTRACTOR TO INCLUDE COST OF THE EQUIPMENT & THE INSTALLATION OF THE EQUIPMENT & COMMISSIONING OF THE SYSTEM TO CITY OF WINNIPEG SATISFACTION & A FULLY WORKING SYSTEM. LOCATION OF KEYPAD IN OFFICE TO BE CONFIRMED ON SITE.

IBASA Electrical Engineering
 ENTERPRISES Design & Consulting
 490 Paul Blvd. Winnipeg, MB R2N 4C8
 T. 204-515-1158
 info@ibasa.ca www.ibasa.ca

COPY RIGHT RESERVED:
 THE CONTRACTOR SHALL VERIFY AND BE RESPONSIBLE FOR ALL DIMENSIONS. DO NOT SCALE THE DRAWING - ANY ERRORS OR OMISSIONS SHALL BE REPORTED TO IBASA ENTERPRISES INC.
 THE COPYRIGHTS TO ALL DESIGNS AND DRAWINGS ARE THE PROPERTY OF IBASA ENTERPRISES INC. REPRODUCTION OR USE FOR ANY PURPOSE OTHER THAN THAT AUTHORIZED BY IBASA ENTERPRISES INC. IS FORBIDDEN.

E				
D	RE-ISSUED FOR CONSTRUCTION	AK	AK	21 02 26
C	RE-ISSUED FOR CONSTRUCTION	AK	AK	21 02 04
B	ISSUED FOR CONSTRUCTION	AK	AK	21 01 30
A	ISSUED FOR REVIEW	AK	AK	21 01 21
ISSUED		BY	APPR.	DATE

SEAL:
APEGM
 Certificate of Authorization
 Ibsa Enterprises Inc.
 No. 5474 Expiry: April 30, 2021



CLIENT: BRIDGMAN COLLABORATIVE ARCHITECTURE
 678 MAIN STREET
 WINNIPEG, MB R3B 1E4
 (204)488-3857
 PROJECT TITLE: LOO LOO WINNIPEG
 715 MAIN ST., WINNIPEG, MB
 BID OPPORTUNITY 54-2021

SHEET TITLE: MAIN LEVEL-LOW VOLTAGE SYSTEMS
 PROJECT NO: 201231
 SCALE: 1/4"=1'-0"
 DESIGNED BY: AK
 DRAWN BY: AK
 REVIEWED BY: AK

SHEET NO:
E02.3