

61-2021 ADDENDUM 2

BERNADINE STRADFORD PARK PLAYGROUND REDEVELOPMENT

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: February 24, 2021
BY: Ian Macdonald
TELEPHONE NO. 204 451-3069

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: A20190115

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART E – SPECIFICATIONS

Revise: E15.2.2: Reinforcing geotextile for indicated area behind retaining wall shall be Combigrid 30/30 Q1 151 GRK 4C, **or Swamp Grid 30**, which are non-woven geotextile/geogrid combinations or approved substitute in accordance with B7.

(a) Contact for Combigrid:

Brock White
879 Keewatin Street Winnipeg, Manitoba
Ph: (204) 694-3600 or 1 (888) 786-6426

(b) Contact for Swamp Grid:

Titan Environmental Containment
777 Quest Blvd, Ile des Chênes, Manitoba
Ph: 1 (866) 327-1957

Note: Accepted Substitute

(c) Technical Data:

(i) Raw Material: Polypropylene/PP

(ii) Nominal Tensile Strength (longitudinal/transverse): min.30 / 30 kN/m

(iii) Tensile Strength at 2% Elongation (long./trans.): min. 12 / 12 KN/m

Note: Accepted Substitute