



658-2021 ADDENDUM 5

NEWPCC AND SEWPCC MEDIUM AND LOW VOLTAGE EQUIPMENT MAINTENANCE SERVICE CONTRACT

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: March 15, 2022
BY: Ryan Salunga
TELEPHONE NO. 204-451-5375

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART B – BIDDING PROCEDURES

- Revise: B14.3 to read: Submit the experience and qualifications (including certificates) of the Key Personnel assigned to the Project to demonstrate experience with projects of similar complexity, scope and value. Include educational background and degrees, professional recognition, job title, years of experience in **current position** and years of experience with existing employer. Roles of each of the Key Personnel in the Project should be identified in the organizational chart referred to in B14.2.1.
- Delete: B14.2 (q) Performing radiography inspection

PART E – SPECIFICATIONS

- Revise: E3.3 to read: The cable tags for MV cables are not provided in the Single Line Drawings (SLD) but the Proponent should base the number of cables to be maintained from the MV cable information provided in the SLD. **The cable maintenance should be price based on the SLD.**

APPENDICES

- Replace: On the NDA document NEWPCC Maintenance Equipment List, the Switchyard Bank 1 Tag ID TVSS-E7013-2 should be using maintenance code 7. Please re-download the revised NEWPCC Maintenance Equipment List.
- Replace: On the NDA document NEWPCC Maintenance Equipment List, the Switchyard Bank 2 Tag ID TVSS-E7023-2 should be using maintenance code 7. Please re-download the revised NEWPCC Maintenance Equipment List document.
- Replace: On the NDA document NEWPCC Maintenance Equipment List, the New Electrical Building Bank 2 Tag ID TCM--E7120-7 and TCM-E7120-9 should be using maintenance code 6. Please re-download the revised NEWPCC Maintenance Equipment List document.
- Replace: On the NDA document NEWPCC Maintenance Schedule and cables checklist, the cable testing should be VLF/TD. Please re-download the revised NEWPCC Maintenance Schedule and cables checklist.

Replace:

On the NDA document SEWPCC Maintenance Schedule and cables checklist, the cable testing should be VLF/TD. Please re-download the revised SEWPCC Maintenance Schedule and cables checklist.