



700-2021 ADDENDUM 1

Japanese Gardens Lighting Upgrades

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID/PROPOSAL

ISSUED: October 20, 2021
BY: Rob Zanewich
TELEPHONE NO. 204 232-2800

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID/PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: Add 2021-03-05

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART E – SPECIFICATIONS

Revise: E9.3.4 to read: Luminaire

- (a) Manufacturer: Selux Corporation
Product Code: SA1L-TS-1-S1G2-40-18-BK-UNV; or
- (b) Manufacturer: U.S. Architectural
Product Code: CLX-LED-VPA-SYM-48LED-NW-120- PT-RAL-9005-S
- (c) Or approved substitution in accordance with B7. Any proposed substitutes must be on the approved products list for Manitoba Hydro’s commercial Power Smart Program.
- (d) Luminaire to be CSA certified and rated for -40°C minimum ambient temperature. Luminaire to be complete with minimum 5 year fixture warranty.
- (e) Driver to have PF > 90%, THD < 20%.
- (f) Surge Suppression to be easily serviceable and must meet or exceed Cat C Low (IEEE C62.41.2).
- (g) In order to receive payment for the luminaires, the Contractor must deliver the Luminaires to the City of Winnipeg owned yard located at 2170 Main Street for storage until the work site installation date. Contact Andy, Foreman 3 at 204 619 2232 to arrange for reception of the goods. The Contractor shall make their own arrangements for loading and unloading of the goods at the City storage site.

Revise: E9.3.6 to read: Bollard Lights

- (a) Manufacturer: Selux Corporation
Product Code: SABL-4-TS-S1G2-40-BK-UNV-HS c/w with anchor bolts; or

- (b) Manufacturer: U.S. Architectural
Product Code: CLXB-LED-WA-36LED-NW-120 – RAL-9005-S c/w anchor bolts.
- (c) In order to receive payment for the bollard lights, the Contractor must deliver the bollards lights to the City of Winnipeg owned yard located at 2170 Main Street for storage until the work site installation date. Contact Andy, Foreman 3 at 204 619 2232 to arrange for reception of the goods. The Contractor shall make their own arrangements for loading and unloading of the goods at the City storage site.

The footings for the bollard lights shall either be poured-in-place concrete or pre-cast concrete, meeting the specifications shown in the Bollard Light Footing Detail on Drawing No. J.3 B.