



## 863-2021 ADDENDUM 1

### JEFFERSON EAST COMBINED SEWER RELIEF – CONTRACT 6B

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE  
BID/PROPOSAL**

ISSUED: February 15, 2022  
BY: Jordan Thompson  
TELEPHONE NO. 204 477 5381

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID/PROPOSAL AND SHALL FORM  
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.**

---

#### **FORM B: PRICES**

Replace: 863-2021 Form B: Prices with 863-2021 Addendum 1 Form B(R1):Prices. The following is a summary of changes incorporated in the replacement Bid/Proposal Submission:

Form B(R1): Revise A.1c) description to read 450mm C76-IV RCP or SDR 35 PVC

#### **PART E – SPECIFICATIONS**

Revise: E21.2 (a) to read: The Contractor will follow the City's Street By-law No. 1481/77 and Street Cuts Manual **(2021)** for all pavement restoration unless otherwise shown on the drawing or specifications or as directed by the Contract Administrator. **The Contractor or their subcontractor shall hold a Restoration Contractor's License issued under the Streets By-law in order to restore pavement cuts in accordance with the City of Winnipeg Street Cuts Manual.**

#### **APPENDICES**

Replace: 863-2021\_Appendix\_A with 863-2021\_Addendum\_1\_Appendix\_A

#### **QUESTIONS AND ANSWERS**

Q1: Can 450mm RCP be used in lieu of 450mm SDR 35 PVC?

A1: Yes.