

APPENDIX B - TABLE E10.2 : SITE SPECIFIC MANHOLE CONDITIONS AND REPAIR REQUIREMENTS

STREET_NAME	LOCATION_DETAILS	MANHOLE_ID	REPAIRS_REQUIRED
1	River Road	MH at Cauchon Street	S-MH60017500 Remove and Replace top 1.6m brick risers with precast concrete risers