

APPENDIX B - TABLE E14.2 : SITE SPECIFIC MANHOLE CONDITIONS AND REPAIR REQUIREMENTS

	STREET_NAME	LOCATION_DETAILS	MANHOLE_ID	REPAIRS REQUIRED
1	Bower Boulevard	1st MH N of Mountbatten Ave	MH60003222	Replace manhole frame
2	Sargent Avenue	MH at Dundas St	MH20009064	Replace manhole cover
3	Gauvin Street	1st MH S of Coniston St	MH50003521	Replace top 2.0m precast conc risers below frame (750 diameter)
4	Gauvin Street	2nd MH S of Coniston St	MH50003522	Replace top 1.0m precast conc risers below frame (750 diameter)
5	Hill Street	MH at Niverville Ave	MH50006432	Replace top 1.1m precast conc risers below frame (750 diameter)
6	Hill Street	1st MH S of Niverville Ave	MH50006439	Replace top 0.3m precast conc risers below frame (750 diameter), Replace manhole cover