



- NOTES:**
- EXISTING MD-1 SHALL REMAIN AND BE MAINTAINED AND BE RENAMED TO SD-1.
 - PROVIDE NEW FEEDER TO EXISTING DISTRIBUTION FROM NEW TRANSFORMER TR-1 ON MAIN FLOOR.
 - EXISTING SECURITY AND FIRE ALARM CONTROL IN BOTTOM OF PANEL SHALL REMAIN.
 - PROVIDE 120V CIRCUIT FOR OWNER SUPPLIED BOSH SYSTEM. COORDITE LOCATION ON SITE.
 - REPLACE EXISTING HORN WITH NEW HORN STROBE. WIRE AND CONNECT TO FIRE ALARM PANEL.
 - PROVIDE NEW STROBE. WIRE AND CONNECT TO NEW FIRE ALARM PANEL.
 - PROVIDE NEW CO DETECTOR C/W SOUNDER BASE. WIRE AND CONNECT TO NEW FIRE ALARM PANEL.
 - PROVIDE NEW SELF CONTAINED EXIST SIGN. WIRE AND CONNECT TO EXISTING EXIT LIGHTING CIRCUIT IN THE AREA.
 - PROVIDE POWER FOR HEAT TRACING. REFER TO MECHANICAL DRAWINGS FOR REQUIREMENTS. EC SHALL WIRE AND CONNECT ALL CONTROLS.



No.	Date	Issue / Revision	By
2	JULY 13, 2022	ISSUED FOR ADD#06	
1	JUNE 21, 2022	ISSUED FOR CONSTRUCTION	DG

Drawn By: MFP
 Printing Date:

Drawings and specifications, as instruments of service are the property of the architects, the copyright in the same being reserved to them. No reproduction may be made without the permission of the architects, and when made, must bear their names. All prints to be returned.

The contractor is to verify dimensions and data noted herein with conditions on the site and is held responsible for reporting any discrepancy to the architects for adjustment.



**CITY OF WINNIPEG
 BONIVITAL POOL RENEWAL**

1215 Archibald St, Winnipeg, MB.

**BASEMENT FLOOR PLAN
 ELECTRICAL**

1 BASEMENT FLOOR PLAN ELECTRICAL
 SCALE: 1:100