

INTERIOR RENOVATION OF BONIVITAL POOL RENEWAL

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID/PROPOSAL

ISSUED: July 19, 2022 BY: Janelle Fillion, LMAG TELEPHONE NO. 204 944-9292

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID/PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART D SUPPLEMENTAL CONDITIONS

Add: D27.1 (c): At the time of systems decommissioning, the City will remove the Cypress pneumatic thermostats, steam trap monitors and Cypress head-end controllers from the building that can be salvaged for re-use in other facilities. Contractor to coordinate with City for removal of devices prior to start of demolition.

PART E - SPECIFICATIONS

Section 01 50 00 Temporary Facilities and Controls

Revise: 1.3.3.2 to read: If existing HVAC system is not available, Contractor to arrange, pay for, operate and maintain temporary heat and ventilation and shelters used during construction, including costs of installation, operation, maintenance and removal of equipment to keep work that requires protection from cold adequately warm and sheltered from elements.

Add: 1.3.3.2.10: Contractor may make use of existing site gas services to operate temporary heat and ventilation system. Cost of gas reasonably used will be provided without charge.

Section 25 05 01 EMCS General Requirements

Delete: 1.5.1.2

DRAWINGS

Replace: 340-2022B_Drawing M7.0-R0 with 340-2022B_Addendum_8_Drawing M7.0-R1

Replace: 340-2022B_Addendum_6_Drawing M8.0-R1 with 340-2022B_Addendum_8_Drawing M8.0-R2

Refer to Addendum 7. Revise this section in Addendum 7 to read:

Replace: 340-2022B_Drawing_E4.0-R1 with 340-2022B_Addendum_6 Drawing E4.0-R2