

556-2022 ADDENDUM 2

JEFFERSON EAST COMBINED SEWER RELIEF - CONTRACT 7A

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID/PROPOSAL

ISSUED: October 21, 2022 BY: Jordan Thompson TELEPHONE NO. 204 928-9222

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID/PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART B - BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, November 1, 2022.

PART E - SPECIFICATIONS

Revise: E21.2(c)(iii) to read: Pavement Restoration Guidelines can be found in the City of Winnipeg Street Cuts

Manual and are summarized below. For Priority II and Priority III streets that are noted to be in "Fair" condition, Bidders shall assume that the "Action Required" will be "Isolated

repairs accepted".

Add: E21.4(c) Permanent Restoration for pavement repairs on Priority II and Priority III streets that are

noted to be in "Fair" condition shall be assumed during bidding to be isolated repairs that will be considered incidental to the Work in accordance with E21.4(a) and will not be measured for payment. If the decision after inspection by Public Works Department requires restoration beyond what would be isolated repairs, the additional restoration will be measured on a unit price basis and payment will be made in accordance with the unit

prices listed on Form B: Prices.

QUESTIONS AND ANSWERS

Q1: Can the 900 mm LDS be upsized to 1050 mm LDS?

A1: The Contractor will be permitted to upsize the 900 mm LDS on Aikins St between Perth Ave and Hartford Ave to 1050 mm LDS. All costs associated with increasing pipe size to accommodate Contractor means and methods shall be borne by the Contractor.