



822-2022 ADDENDUM 1

**WPS VEHICLE INSPECTION FACILITY FOUNDATION UPGRADES
44 BANGOR AVENUE**

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: November 23, 2022
BY: Andy Urbanowicz
TELEPHONE NO. 204 308-3931

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, **November 29, 2022**.

QUESTIONS AND ANSWERS

Q1: Will asphalt removed/damaged during the work require repair?

A1: Yes, removed or damaged asphalt shall be repaired. This work will be considered seasonal work to be completed in the spring. Liquidated damages will not be applicable.

Q2: Please provide details for mechanical and electrical disconnect / connections to occur.

A2: Existing electrical service to be removed/relocated as required and reinstated as existing upon completion of the Work. Mechanical disconnect/connection is not applicable.