



307-2023 ADDENDUM 2

2023 SEWER RENEWALS BY EXTERNAL POINT REPAIRS AND FULL SEGMENT RENEWALS – CONTRACT 1

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID/PROPOSAL

ISSUED: May 23, 2023
BY: Rob Sherlock
TELEPHONE NO. 204 478-8993

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID/PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: Add 2021-03-05

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

FORM B: PRICES

Replace: 307-2023 Form B: Prices with 307-2023 Addendum 2 - Form B: Prices. The following is a summary of changes incorporated in the replacement Bid/Proposal Submission:

- Form B(R1): Revised Item D.1 based on type of backfill; and
- Revised Item F.6 to reference specification E20.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, May 26, 2023.

PART E – SPECIFICATIONS

- Revise: E17.10. to read: Take appropriate measures to ensure panels are not displaced during backfilling operations. Backfilling to be in accordance with SD-018.
- Revise: E17.11. to read: Insulation of existing sewer shall be measured on a length basis, and for each type of backfill, and paid for at the Contract Unit Price per meter of “Insulation of Existing Sewer”. The length to be paid for shall be the total number of linear meters of existing sewer pipe insulated, supplied and installed in accordance with this specification, accepted and measured by the Contract Administrator.
- Add: E20 **CONSTRUCTION OF ASPHALTIC CONCRETE PATCHES**
- Add: E20.1 Asphalt Patching shall be constructed, measured and paid for as per CW 3410 except that patches in excess of 1.5 metres in width will still be considered as asphalt patches. Furthermore, the Contractor shall place and compact base course material to a minimum thickness of 150mm.