Drawing Title:

Drawing No:

SCD-668

Drain Basin

LOCKABLE STANDARD DUCTILE IRON GRATE AND FRAME. DIAMETER AS PER DRAWINGS NON-WOVEN GEOTEXTILE. GEOTEXTILE TO BE WRAPPED AND PLACED BETWEEN CRUSHED LIMESTONE AND TOPSOIL/BACKFILL SLOPE FINAL SOD GRADE AS 150 150 SPECIFIED ON DRAWINGS TOPSOIL AND SOD AS PER **DRAWINGS** NYLOPLAST PERFORATED RISER SECTION PER MANUFACTURER'S **NVERT HEIGHT AS PER DRAWINGS** PERFORATION SCHEDULE OR APPROVED EQUAL. DIAMETER AS PER DRAWINGS 19mm CLEAN CRUSHED LIMESTONE FIELD GLUE JOINT AS PER MANUFACTURER'S SPECIFICATIONS NYLOPLAST DRAIN BASIN OR APPROVED EQUAL. DIAMETER AS PER DRAWINGS INITIAL BACKFILL IN ACCORDANCE WITH CW 2030 AND SD-001 MINIMUM 200mm DIAMETER LEAD TO CATCH BASIN SIZED, SLOPED AND LOCATED AS PER DRAWINGS BEDDING IN ACCORDANCE WITH CW 2030 AND SD-001 300mm DEPTH SUMP - SUBGRADE

DIMENSIONS SHOWN ARE IN MILLIMETRES UNLESS OTHERWISE SPECIFIED

REVISION: R0

June 29, 2023 DATE:

N.T.S. SCALE: TB DRAWN BY:

The City of Winnipeg Planning, Property and Development Department

Planning and Land Use Division

Unit 15 - 30 Fort Street, Winnipeg, MB, R3C 4X5

