



471-2023 ADDENDUM 1

SUPPLY AND DELIVERY OF SODIUM HYDROXIDE FOR NORTH END SEWAGE TREATMENT PLANT (NEWPCC)

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: November 9, 2023
BY: Erica Campbell
TELEPHONE NO. 204 986-3150

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

Revise: D15.1 to read: If the Contractor fails to achieve delivery of the goods within the time specified in D13.1.1, the Contractor shall pay the City one thousand dollars (\$1,000) Per Working Day for each and every Working Day **until the goods have been delivered.**

PART E – SPECIFICATIONS

Revise: E2.2(v) to read: Percent concentration; (28.5% to 31%)