



623-2023 ADDENDUM 3

HORIZONTAL DIRECTIONAL DRILLING (PIT LAUNCH) TO INSTALL COPPER WATER SERVICES 19MM TO 50 MM

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: JANUARY 19, 2024
BY: Dennis Kwast
TELEPHONE NO. 431-336-1767

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

FORM B: PRICES

Replace: 623-2023 Addendum 2 - Form B: Prices with 623-2023 Addendum 3 - Form B: Prices. The following is a summary of changes incorporated in the replacement Bid/Proposal Submission:

Add: Part C - Weekend and Statuary Holidays Standby Rate

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The submission Deadline is 4:00 p.m. Winnipeg time, January 24, 2024.

QUESTIONS AND ANSWERS

Q1: Who is responsible for daylighting utilities along the bore path?

A1 The Contractor needs to assess risks and discuss any daylighting needs with the City representative as per clause D2.3(b) and D3.2(b). The City will decide which utilities should be daylighted and cover the associated costs.

Q2: What if the trench cage needs to be moved or adjustment to the depth of the pit required?

A2 As per D2.3 (c)(ii) Addendum 2; the City will adjust the depth and relocate the pit and cage as required.