## **ASBESTOS INVENTORY CONTROL**



Assets and Project Management Department Municipal Accommodations Division 4th Floor - 185 King Street • Winnipeg, MB • R3B 1J1

Building Name:	John Blumberg Park	Inspection Date:	August 15, 2023
Building Code:	P-268	Inspected By:	Ryan Matthews
Building Address:	4540 Portage Ave.	Construction Date:	

		Drawing	Material	Testing	Date	Test	Est.
Material Location	Material Description	Label	Condition	Status	M/Y	%	%
NOTES:	<u> </u>	•		•	•	<u> </u>	
1. Asbestos inspections and inventory upda							
	rials present that were not located during asbestos inspections.	material			D	26	0
<ol> <li>Floor tile and sheet flooring installed before 1990 may contain asbestos and must be treated as an asbestos containing material.</li> <li>Vermiculite insulation may contain pockets of asbestos. All vermiculite insulation must be treated as an asbestos containing material.</li> </ol>					P-	<b>Z</b> 0	0
5. For asbestos related inquiries, call Central Control at 986-2382							
P-2681 Main Concession							
Office	Sheet Flooring (3 Samples Taken)	FS	Good	TESTED	Sep/'16	0	
Mechanical Room	Mastic- Duct Red/ Brown	MA	Good	TESTED	Jun/'18	8	
	Pipe Fitting (Potentially in Crawlspace)	PF	Good				
Women's W/C	Drywall Compound	DC	Good	TESTED	Jun/'18	0	
Men's WC	Drywall Compound	DC	Good	TESTED	Jun/'18	0	
Kitchen/ Canteen	Drywall Compound	DC	Good	TESTED	Jun/'18	0	
	Sheet Flooring (3 Samples Taken)	FS	Good	TESTED	Sep/'16	0	
2nd Floor Lobby/ Eating Area	Drywall Compound	DC	Good	TESTED	Jun/'18	0	
	Drywall Compound (3 Samples Taken)	DC	Good	TESTED	Sep/'16	0	
	12x12 Floor Tile (3 Samples Taken)	F12	Good	TESTED	Sep/'16	0	
2nd Floor Kitchen/ Canteen	Drywall compound (3 Samples Taken)	DC	Good	TESTED	Sep/'16	0	
P-2682 Announcer's Box							
Upper Floor	12x12 Floor Tile	F12	Good	TESTED	Jun/'18	0	
P-2683 Storage Garage/ Shop	No Asbestos Containing Materials Located						
P-2684 Secondary Concession	No Asbestos Containing Materials Located						
P-2685 Storage Shed South	No Asbestos Containing Materials Located						
P-2686 Main Entrance Booth	No Asbestos Containing Materials Located						
P-2687 Irrigation Pumphouse	No Asbestos Containing Materials Located						
P-2688 Storage Shed	No Asbestos Containing Materials Located						
P-2689 Storage Shed	No Asbestos Containing Materials Located						
P-270 Irrigation Pumphouse	No Asbestos Containing Materials Located						


		Drawing	Material
Material Location	Material Description	Label	Condition
P-271 Service Garage	No Asbestos Containing Materials Located		
P-2711 Storage Shed	No Asbestos Containing Materials Located		
	Asphalt Roof Shingles (3 samples taken)		Needs Repair

Testing Status	Date M/Y	Test %	Est. %
TESTED	Jul/'23	0	

## NOTES:

- 1. Asbestos inspections and inventory updates are conducted annually.
- 2. There may be asbestos containing materials present that were not located during asbestos inspections.
- 3. Floor tile and sheet flooring installed before 1990 may contain asbestos and must be treated as an asbestos containing material.
- 4. Vermiculite insulation may contain pockets of asbestos. All vermiculite insulation must be treated as an asbestos containing material.
- 5. For asbestos related inquiries, call Central Control at 986-2382

P-268





AF: ASBESTOS FABRIC BR: BOILER REFRACTORY CA: CAULKING

C12: 12X12 CEILING TILE C24: 24X24 CEILING TILE C48: 24X48 CEILING TILE

DC: DRYWALL COMPOUND DI: DUCT INSULATION

FS: SHEET FLOORING

BUILDING:

REVISED BY:

REM

P-268 JOHN BLUMBERG PARK 4540 PORTAGE AVE. WINNIPEG, MANITOBA DATE: SHEET #: SCALE:

July 14, 2020

N.T.S.

1/1



PLANNING, PROPERTY & DEVELOPMENT DEPARTMENT MUNICIPAL ACCOMMODATIONS DIVISION 4th FLOOR - 185 KING STREET

WINNIPEG, MANITOBA R3B 1J1 PHONE: (204) 986-7266 FAX: (204) 986-7311

PL: PLASTER RD: ROOF DRAIN

PF: PIPE FITTING INSULATION VE: VERMICULITE

ST: STUCCO

TI: TANK INSULATION

TP: TRANSITE PIPE

F12:12X12 FLOOR TILE

PI: PIPE INSULATION

HB: HARDBOARD

MA: MASTIC