

1 E1.1 SITE PLAN ELECTRICAL
SCALE: 1:100

NOTES:

1. DISCONNECT AND REMOVE EXISTING MAIN UNDERGROUND FEEDER. FEEDER RUNS UNDER RAMP AND SHALL BE ABANDONED.
2. EXISTING MAIN DISTRIBUTION SHALL REMAIN IN EXISTING ELECTRICAL ROOM IN BASEMENT AND SHALL BE RE-LABELLED AS SD-1.
3. DISCONNECT AND REMOVE WIRING ASSOCIATED WITH EXISTING CONDENSING UNIT IN THIS LOCATION.
4. DISCONNECT EXISTING AIR HANDLING UNIT AT THIS LOCATION AND RELOCATE TO NEW LOCATION SHOWN. WIRE AND CONNECT TO EXISTING BREAKER WITH EXISTING WIRING EXTENDED/REROUTED AS REQUIRED.
5. PROVIDE CODE COMPLIANT ROOF SERVICE RECEPTACLE AS PER DETAIL 2/E1.1.



2 E1.1 ROOF RECEPTACLE DETAIL
SCALE: N.T.S.

PROVINCE OF MANITOBA
2023-12-21
K. E. ISAAK
REGISTERED PROFESSIONAL ENGINEER

ENGINEERS GEOSCIENTISTS MANITOBA
Certificate of Authorization
MCW Consultants Ltd.
No. 7183

THIS IS A PRINT OF A DOCUMENT THAT HAS BEEN ELECTRONICALLY AUTHENTICATED WITH TECHNOLOGY AUTHORIZED BY THE EGM. THE ORIGINAL IS IN ELECTRONIC FORM.

MCW
MCW Consultants Ltd.
210-1821 Wellington Avenue
Winnipeg, Manitoba, R3H 0G4
Phone - (204) 775-7300
mcw_wpg@mcw.com
www.mcw.com

13600

No.	Date	Issue / Revision	By
0	22/12/2023	ISSUED FOR CONSTRUCTION	DG

Drawn By: MFP
Printing Date: 22/12/2023

Drawings and specifications, as instruments of service are the property of the architects, the copyright in the same being reserved to them. No reproduction may be made without the permission of the architects, and when made, must bear their names. All prints to be returned.

The contractor is to verify dimensions and data noted herein with conditions on the site and is held responsible for reporting any discrepancy to the architects for adjustment.

LM Architectural Group
500-136 Market Ave
Winnipeg Manitoba Canada R3B 0P4
t: (204) 942.0691 f: (204) 943.8676
www.lm-architects.com

CITY OF WINNIPEG
BONIVITAL POOL RENEWAL

1215 Archibald St, Winnipeg, MB.

SITE PLAN ELECTRICAL

Comm. No.: 2129 Sheet: **E1.1**
Plotted on: 2023-12-22