

1 M9.0 ELECTRICAL ROOM VENTILATION
SCALE: NTS



2 M9.0 WALL FIN
SCALE: NTS



3 M9.0 DOMESTIC HOT WATER RECIRC PUMP CONTROL
SCALE: NTS



4 M9.0 RADIANT PANEL
SCALE: NTS



5A M9.0 EXHAUST FAN (TYPICAL)
SCALE: NTS



5B M9.0 EXHAUST FAN (TYPICAL)
SCALE: NTS



6 M9.0 AIR HANDLING UNITS AHU-2
SCALE: NTS

EXISTING HRV TO REMAIN AND ALL POINTS FROM EXISTING CONTROL SYSTEMS TO NEW SYSTEM

7 M9.0 EXISTING HRV
SCALE: NTS



10 M9.0 NATATORIUM AIR HANDLING UNIT AHU-1
SCALE: NTS

PROVIDE FOR THE FOLLOWING DRY CONTACTS (NOT SHOWN)
1. GENERAL ALARM
2. BLOWER INTERLOCK
3. STAGE 1 / 2 HEATING
4. OUTDOOR AIR DAMPER
5. EXHAUST FAN 1
6. EXHAUST FAN 2
7. OUTDOOR AIR COOLED EQUIP ALARM
8. SYSTEM STATUS
9. AUXILIARY POOL HEATER STATUS
10. HEAT RECOVERY STATUS



8 M9.0 NEW HEATING PLANT BOILERS B-1 & B-2
SCALE: NTS



9 M9.0 NEW EMCS SYSTEM ARCHITECTURE
SCALE: NTS



11 M9.0 CABINET UNIT HEATERS
SCALE: NTS



12 M9.0 DUCT HEATING COIL
SCALE: NTS

ENGINEERS GEOSCIENTISTS MANITOBA
Certificate of Authorization
MCW Consultants Ltd.
No. 7183

THIS IS A PRINT OF A DOCUMENT THAT HAS BEEN ELECTRONICALLY AUTHENTICATED WITH TECHNOLOGY AUTHORIZED BY THE EGM. THE ORIGINAL IS IN ELECTRONIC FORM.

MCW Consultants Ltd.
13600
210-1921 Wellington Avenue
Winnipeg, Manitoba, R3H 0G4
Phone – (204) 775-7300
mcw_wpg@mcw.com
www.mcw.com

No.	Date	Issue / Revision	By
0	22/12/2023	ISSUED FOR CONSTRUCTION	JVL

Drawn By: EJ
Printing Date: 22/12/2023

PROVINCE OF MANITOBA
J.E. VAN LEEUWEN
Member 36282
REGISTERED PROFESSIONAL ENGINEER
2023-12-21

Drawings and specifications, as instruments of service are the property of the architects, the copyright in the same being reserved to them. No reproduction may be made without the permission of the architects, and when made, must bear their names. All prints to be returned.

The contractor is to verify dimensions and data noted herein with conditions on the site and is held responsible for reporting any discrepancy to the architects for adjustment.

LM Architectural Group
500-136 Market Ave
Winnipeg Manitoba Canada R3B 0P4
t: (204) 942.0681 f: (204) 943.8676
www.lm-architects.com

CITY OF WINNIPEG
BONIVITAL POOL RENEWAL

1215 Archibald St, Winnipeg, MB.

CONTROL SCHEMATICS

Comm. No.: 2129 Sheet: **M9.0**
Plotted on: