

1 EL2.1 MAIN FLOOR PLAN LIGHTING
SCALE: 1:100



2 EL2.1 MPR / SAUNA FLOOR PLAN LIGHTING
SCALE: 1:100

NOTES:

1. WIRE AND CONNECT EXISTING 1x4 LED LUMINAIRE IN NEW LOCATION AS SHOWN.
2. PROVIDE SELF CONTAINED EMERGENCY LIGHTING HEAD. WIRE AND CONNECT TO EXISTING LIGHTING CIRCUIT IN ROOM.
3. PROVIDE NEW RUNNING MAN EXIT SIGN. WIRE AND CONNECT TO EXISTING EXIT LIGHTING CIRCUIT.
4. REPLACE EXISTING EXIT SIGN WITH NEW RUNNING MAN EXIT SIGN. WIRE AND CONNECT TO EXISTING CIRCUIT.
5. EXISTING LIGHTING SHALL REMAIN AND BE MAINTAINED.
6. SAUNA LIGHTING SHALL BE CONTROLLED FROM COPY AREA.
7. RELOCATE EXISTING LIGHTING CONTROL TO NEW LOCATION SHOWN AND PROVIDE NEW RECESSED PANEL.
8. PROVIDE NEW INDIRECT LIGHTING IN POOL AREA. REUSE EXISTING CIRCUIT TO FEED NEW LAYOUT. PROVIDE NEW CONDUIT AND WIRING TO MEET CEC SECTION 22.
9. REPLACE EXISTING WALL MOUNTED LIGHTING ON EMERGENCY POWER IN POOL AREA WITH NEW TYPE 'J' LUMINAIRE.
10. RELOCATE/RECONNECT EXISTING PHOTOCELL IN THIS LOCATION FOR EXISTING EXTERIOR LIGHTING.
11. PROVIDE NEW PHOTOCELL ON ROOF OF CANOPY FOR NEW CANOPY LIGHTING.
12. TYPE D8A LUMINAIRE SHALL BE SUSPENDED FROM T-BAR CEILING AND SHALL FOLLOW THE LINE ON THE POOL CEILING REFER TO ARCH. SECTIONS FOR MOUNTING HEIGHT.
13. TYPE D8B LUMINAIRE SHALL BE SUSPENDED FROM CEILING STRUCTURE AND SHALL BE MOUNTED 6" BELOW CEILING GRID.
14. ALL NEW WIRING IN POOL AREA FOR THE NEW LIGHTING SHALL MEET ALL REQUIREMENT OF SECTION 22 OF THE CEC.

PROVINCE OF MANITOBA
2023-12-21
K.E. ISAAK
REGISTERED PROFESSIONAL ENGINEER

ENGINEERS
GEOSCIENTISTS
MANITOBA
Certificate of Authorization
MCW Consultants Ltd.
No. 7183

"THIS IS A PRINT OF A DOCUMENT THAT HAS BEEN ELECTRONICALLY AUTHENTICATED WITH TECHNOLOGY AUTHORIZED BY THE EGM. THE ORIGINAL IS IN ELECTRONIC FORM."

MCW
MCW Consultants Ltd.
13600
210-1821 Wellington Avenue
Winnipeg, Manitoba, R3H 0G4
Phone – (204) 775-7300
mcw_wpg@mcw.com
www.mcw.com

No.	Date	Issue / Revision	By
0	22/12/2023	ISSUED FOR CONSTRUCTION	DG

Drawn By: MFP
Printing Date: 22/12/2023

Drawings and specifications, as instruments of service are the property of the architects, the copyright in the same being reserved to them. No reproduction may be made without the permission of the architects, and when made, must bear their names. All prints to be returned.

The contractor is to verify dimensions and data noted herein with conditions on the site and is held responsible for reporting any discrepancy to the architects for adjustment.

LM Architectural Group
500-136 Market Ave
Winnipeg Manitoba Canada R3B 0P4
t: (204) 942.0691 f: (204) 943.8676
www.lm-architects.com

CITY OF WINNIPEG
BONIVITAL POOL RENEWAL

1215 Archibald St, Winnipeg, MB.

MAIN FLOOR PLAN LIGHTING

Comm. No.: 2129 Sheet: **EL2.1**
Plotted on: 22-12-23