



929-2023 ADDENDUM 1

SOUTH END WATER POLLUTION CONTROL CENTRE (SEWPCC) B679 CHILLER REPLACEMENT

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: April 5, 2024
BY: Scott Begg, P.Eng.
TELEPHONE NO. 431-489-9010

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2024-02-01

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

DRAWINGS

Add: 929-2023_Addendum_1_1-0102-CGAD-A002
929-2023_Addendum_1_1-0102-CGAD-A003
929-2023_Addendum_1_1-0102B-E0001-001
929-2023_Addendum_1_1-0102B-E0002-001
929-2023_Addendum_1_1-0102P-E0009-001

QUESTIONS AND ANSWERS

- Q1: Can we get a site layout with scalebar?
A1: Please refer to additional drawings for reference only.
- Q2: Can we use a scissor lift?
A2: A small scissor lift will fit and can be lowered with the hoist. The scissor lift would need to be contractor supplied.
- Q3: Can you please confirm that the required damper on the drawing (BDD-B682) is to follow the spec for the conventional Aluminium, Counterbalanced, Heavy Duty damper? We've checked the detail 2331-110 and it is unclear which damper is required.
A3: Confirmed.