



954-2023B ADDENDUM 4

PEMBINA TRAILS COLLECIATE – VOCATIONAL WING

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: May 6, 2024
BY: Jon Trenholm
TELEPHONE NO. 204-942-0681

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2024-02-01

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

DRAWINGS

Replace: 954-2023B _Drawing_Addendum_3-A2.1-R1 with 954-2023B _Addendum_4-Drawing_A2.1-R2

954-2023B _Drawing_A5.1 with 954-2023B _Addendum_4-Drawing_A5.1-R1

954-2023B _Drawing_A5.2 with 954-2023B _Addendum_4-Drawing_A5.2-R1

954-2023B _Drawing_A5.3 with 954-2023B _Addendum_4-Drawing_A5.3-R1

954-2023B _Drawing_A5.4 with 954-2023B _Addendum_4-Drawing_A5.4-R1

954-2023B_Addendum_1-Drawing_E6.11-R1 with drawing 954-2023B_Addendum_4-Drawing_E6.11-R2.

NMS SPECIFICATIONS

Section 01 11 00 Summary of Work

Delete: 1.11

Section 07 42 13.20 Acoustic Barrier Panel System

Replace Section 07 42 13.20 with 954-2023B_Addendum_4-NMS_Section-#074213.20R1

Section 08 71 01 Door Hardware Sets

Replace 954-2023B_Addendum_3-NMS_Section-#087101R2 with 954-2023B_Addendum_4-NMS_Section-#087101R3

Section 09 06 00 Room Finish Schedule

Replace 954-2023B_Addendum_3-NMS_Section-#090600R1 with 954-2023B_Addendum_4-NMS_Section-#090600R2

Section 09 29 00 Gypsum Board

Revise 2.2.5 to read: Fire-Rated Very High Impact (VHI) Gypsum Board (where indicated): to ASTM C1396/C1396M, ASTM C1629/C1629M, and ASTM E136, 16 mm thick Type X fire-rated very high impact-resistant (VHI) paper-faced panels with moisture and mould resistance, 1220 mm wide x maximum practical length, ends square factory cut, edges tapered.

Section 11 40 10 Food Service Equipment - Catalogued

Replace 954-2023B_Addendum_3-NMS_Section-#114010R1 with 954-2023B_Addendum_4-NMS_Section-#114010R2

Section 22 10 00 Plumbing Piping

Delete: 3.8

Architectural Project Manual Details

Add: 954-2023B_Addendum_4 NMS_Figure-AP5.09
954-2023B_Addendum_4 NMS_Figure-AP5.10
954-2023B_Addendum_4 NMS_Figure-AP5.11
954-2023B_Addendum_4 NMS_Figure-AP5.12
954-2023B_Addendum_4 NMS_Figure-AP5.13
954-2023B_Addendum_4 NMS_Figure-AP5.14
954-2023B_Addendum_4 NMS_Figure-AP5.15
954-2023B_Addendum_4 NMS_Figure-AP5.16

QUESTIONS AND ANSWERS

- Q1: Addendum No.03 A13 incorrectly indicates to refer to Drawing Sheet 954-2023B_Addendum_2-Drawing_A5.2-R1.
A1: Revised Architectural Drawing issued in Addendum No. 04.
- Q2: Rooms 1M:02 and 1M:03 call for an EFP floor finish. This is not in the legend. What kind of material is this?
A2: EFP is an Epoxy Floor Paint for service rooms, refer also to Project Manual section 09 00 00.
- Q3: Panelboard M2C and M2D are the wrong size. They are 225A Panels fed by 400A breakers. Please Advise.
A3: Refer to drawings in this addendum.